

Aquarion Water Company of New Hampshire

Results of Per and Poly Flouro Alkyl Substances (PFASs) Testing, 2014 - 2019

7/25/2019

All results are in parts per trillion (ppt)

The testing method has been evolving over the past several years.  
Laboratories are now able to detect and quantify PFAS at lower levels than before.  
Laboratories are now able to detect more PFAS compounds than before (26 compared to 6).

EPA lifetime Health Advisory Limit (HAL) = 70 ng/L  
- HAL applies to PFOA, PFOS and PFOA + PFOS only  
NHDES Ambient Ground Water Quality Standard = 70 ppt  
ND = Not Detected  
NT = Not Tested

Color Key:

up to 7 ppt = 10% HAL   up to 17.5 ppt = 25% HAL   up to 35 ppt = 50% HAL   up to 52.5 ppt = 75% HAL   up to 70 ppt = 100% HAL   above the HAL of 70 ppt

| Sample Date     | Perfluorooctanoic acid PFOA | Perfluorooctane-sulfonate PFOS | Total PFOA + PFOS | Perfluoroheptanoic acid PFHpA | Perfluorobutane-sulfonate PFBS | Perfluorohexane-sulfonate PFHxS | Perfluorononanoic acid PFNA | Perfluorohexanoic acid PFHxA | Perfluorobutanoic acid PFBA | Perfluoropentanoic acid PFPeA | 6:2 Fluorotelomer sulfonate 6:2 FTS | Total PFAS | Comments                        |
|-----------------|-----------------------------|--------------------------------|-------------------|-------------------------------|--------------------------------|---------------------------------|-----------------------------|------------------------------|-----------------------------|-------------------------------|-------------------------------------|------------|---------------------------------|
| Well 5A         |                             |                                |                   |                               |                                |                                 |                             |                              |                             |                               |                                     |            |                                 |
| 15-Sep-2014     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         | 6 PFAS tested                   |
| 10-Mar-2015     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         | 6 PFAS tested                   |
| 25-Jul-2016     | 4                           | ND < 10 ppt                    | 4                 | 1                             | ND < 10                        | ND < 10 ppt                     | ND < 2 ppt                  | 2                            | NT                          | NT                            | NT                                  | 7          | 12 PFAS tested                  |
| 6-Jun-2017      | 2                           | 3                              | 5                 | 0.7                           | 1                              | ND < 3 ppt                      | ND < 2 ppt                  | 0.8                          | NT                          | NT                            | NT                                  | 7.5        | 14 PFAS tested                  |
| 1-Aug-2017      | 2.44                        | 3.05                           | 5.49              | ND < 4 ppt                    | ND < 4 ppt                     | 1.25                            | ND < 4 ppt                  | ND < 4 ppt                   | NT                          | NT                            | NT                                  | 6.74       | 14 PFAS tested                  |
| 24-Aug-2017     | 3.25                        | 2.96                           | 6.21              | ND < 4.37                     | ND < 4.37                      | 2.02                            | ND < 4.37                   | ND < 4.37                    | NT                          | NT                            | NT                                  | 8.23       | 14 PFAS tested                  |
| 19-Sep-2017     | 1.89                        | 3.6                            | 5.49              | ND < 4.15                     | ND < 4.15                      | ND < 4.15                       | ND < 4.15                   | ND < 4.15                    | NT                          | NT                            | NT                                  | 5.49       | 14 PFAS tested                  |
| 17-Oct-2017     | 1.46                        | 4.13                           | 5.59              | ND < 4.20                     | ND < 4.20                      | ND < 4.20                       | ND < 4.20                   | ND < 4.20                    | ND < 4.20                   | ND < 4.20                     | ND                                  | 5.59       | 26 PFAS tested                  |
| 14-Nov-2017     | 3.53                        | 3.13                           | 6.66              | ND < 4.19                     | ND < 4.19                      | ND < 4.19                       | ND < 4.19                   | ND < 4.19                    | 1.47                        | ND < 4.19                     | ND                                  | 8.13       | 26 PFAS tested                  |
| 13-Dec-2017     | 7.24                        | 2.18                           | 9.42              | 0.82                          | ND < 4.30                      | 1.32                            | ND < 4.30                   | ND < 4.30                    | 1.74                        | 1.51                          | ND                                  | 14.81      | 26 PFAS tested                  |
| 23-Jan-2018     | 2.17                        | 3.36                           | 5.53              | 1.03                          | ND < 4.20                      | 1.17                            | ND < 4.20                   | ND < 4.20                    | ND < 4.20                   | ND < 4.20                     | ND                                  | 7.73       | 26 PFAS tested                  |
| 14-Feb-2018     | 3.71                        | 0.905                          | 4.615             | ND < 4.19                     | 1.97                           | ND < 4.19                       | ND < 4.19                   | ND < 4.19                    | 1.46                        | 1.4                           | ND                                  | 9.445      | 26 PFAS tested                  |
| 2-May-2018      | 3.92                        | 2.51                           | 6.43              | ND < 4.20                     | ND < 4.20                      | ND < 4.20                       | ND < 4.20                   | ND < 4.20                    | 1.14                        | ND < 4.20                     | ND < 4.20                           | 7.57       | 26 PFAS tested                  |
| 9-Aug-2018      | 4.22                        | 2.66                           | 6.88              | 1.07                          | ND < 4.21                      | 1.08                            | ND < 4.21                   | ND < 4.21                    | 2.14                        | 1.53                          | ND < 4.21                           | 12.70      | 26 PFAS tested                  |
| 11-Feb-2019     | 2.67                        | 3.20                           | 5.87              | 0.82                          | ND < 4.50                      | ND < 4.50                       | ND < 4.50                   | ND < 4.50                    | 1.57                        | ND < 4.50                     | ND < 4.50                           | 8.26       | 26 PFAS tested                  |
| 7-May-2019      | 1.67                        | 2.37                           | 4.04              | 0.748                         | ND < 4.23                      | ND < 4.23                       | ND < 4.23                   | ND < 4.23                    | 1.32                        | ND < 4.23                     | ND < 4.23                           | 6.11       |                                 |
| Well 7          |                             |                                |                   |                               |                                |                                 |                             |                              |                             |                               |                                     |            |                                 |
| 15-Sep-2014     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         |                                 |
| 11-Mar-2015     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         |                                 |
| 25-Jul-2016     | 3                           | ND < 10 ppt                    | 3                 | 1                             | ND < 10 ppt                    | ND < 10 ppt                     | ND < 2 ppt                  | 1                            | NT                          | NT                            | NT                                  | 5          |                                 |
| 1-Aug-2017      | 1.77                        | 2.64                           | 4.41              | ND < 4 ppt                    | ND < 4 ppt                     | 1.58                            | ND < 4 ppt                  | ND < 4 ppt                   | NT                          | NT                            | NT                                  | 5.99       |                                 |
| 24-Aug-2017     | 2.47                        | ND < 4.31                      | 2.47              | ND < 4.31                     | ND < 4.31                      | 1.39                            | ND < 4.31                   | ND < 4.31                    | NT                          | NT                            | NT                                  | 3.86       |                                 |
| 15-Nov-2017     | 1.50                        | ND < 4.72                      | 1.50              | ND < 4.72                     | 2.12                           | ND < 4.72                       | ND < 4.72                   | ND < 4.72                    | 1.70                        | ND < 4.72                     | ND                                  | 5.32       |                                 |
| 14-Feb-2018     | 5.85                        | ND > 4.21                      | 5.85              | ND < 4.21                     | 2.59                           | ND < 4.21                       | ND < 4.21                   | ND < 4.21                    | 1.46                        | ND < 4.21                     | ND                                  | 9.9        |                                 |
| 9-Aug-2018      | 4.47                        | 2.17                           | 6.64              | 1.23                          | 2.19                           | 1.24                            | ND < 4.27                   | ND < 4.27                    | 2.39                        | 1.62                          | ND < 4.27                           | 15.31      |                                 |
| 11-Feb-2019     | 4.07                        | 1.92                           | 5.99              | 1.69                          | 2.33                           | 1.79                            | ND < 4.29                   | ND < 4.29                    | 2.48                        | 1.72                          | ND < 4.29                           | 16.00      |                                 |
| 7-May-2019      | 5.01                        | 1.93                           | 6.94              | 2.23                          | 2.88                           | 1.36                            | ND < 4.18                   | ND < 4.18                    | 1.80                        | 2.31                          | ND < 4.18                           | 17.52      |                                 |
| Well 14         |                             |                                |                   |                               |                                |                                 |                             |                              |                             |                               |                                     |            |                                 |
| 15-Jun-2014     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         |                                 |
| 11-Mar-2015     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         |                                 |
| 25-Jul-2016     | 4                           | ND < 10 ppt                    | 4                 | 2                             | ND < 10 ppt                    | ND < 10 ppt                     | ND < 2 ppt                  | 3                            | NT                          | NT                            | NT                                  | 9          |                                 |
| 6-Jun-2017      | 4                           | 3                              | 7                 | 2                             | 2                              | 1                               | ND < 2 ppt                  | 3                            | NT                          | NT                            | NT                                  | 15         |                                 |
| 24-Aug-2017     | 4.38                        | 3.21                           | 7.59              | 0.747                         | 3.87                           | 1.51                            | ND < 4.34                   | ND < 4.34                    | NT                          | NT                            | NT                                  | 13.717     |                                 |
| 19-Sep-2017     | 3.48                        | 4.18                           | 7.66              | 0.884                         | 4.08                           | 1.07                            | ND < 4.21                   | 3.39                         | NT                          | NT                            | NT                                  | 17.084     |                                 |
| 16-Oct-2017     | 4.13                        | 2.75                           | 6.88              | 1.32                          | 7.22                           | 1.01                            | ND < 4.14                   | 3.42                         | 1.51                        | 3.65                          | ND                                  | 25.01      | well off-line                   |
| 14-Nov-2017     | 8.82                        | 4.21                           | 13.03             | 1.77                          | 6.9                            | ND < 4.41                       | ND < 4.41                   | 3.06                         | 2.15                        | 4.13                          | ND                                  | 31.04      | well off-line                   |
| 13-Dec-2017     | 5.52                        | 3.50                           | 9.02              | 0.973                         | 6.11                           | 1.91                            | ND < 4.22                   | 3.30                         | 1.69                        | 3.18                          | ND                                  | 26.18      | well off-line                   |
| 23-Jan-2018     | 2.38                        | 5.56                           | 7.94              | 1.55                          | 7.5                            | 1.92                            | ND < 4.23                   | ND < 4.23                    | 1.91                        | 3.35                          | ND                                  | 24.17      | well off-line                   |
| 10-Jul-2018     | 5.31                        | 1.72                           | 7.03              | ND < 4.05                     | 4.52                           | 2.6                             | 1.07                        | 3.58                         | ND < 4.05                   | 3.17                          | ND < 4.05                           | 21.97      | well in service                 |
| 9-Aug-2018      | 5.43                        | 4.23                           | 9.66              | 1.67                          | 3.70                           | 1.62                            | ND < 4.19                   | 4.37                         | 3.02                        | 4.17                          | ND < 4.19                           | 28.21      | well in service                 |
| 11-Feb-2019     | 4.95                        | 3.36                           | 8.31              | 1.84                          | 2.23                           | 1.15                            | ND < 4.18                   | 3.82                         | 2.35                        | 3.47                          | ND < 4.18                           | 23.17      | well in service                 |
| MILL ROAD WELLS |                             |                                |                   |                               |                                |                                 |                             |                              |                             |                               |                                     |            |                                 |
| Well 6          |                             |                                |                   |                               |                                |                                 |                             |                              |                             |                               |                                     |            |                                 |
| 16-Sep-2014     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | ND < 10 ppt                   | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | ND         |                                 |
| 14-Apr-2015     | ND < 20 ppt                 | ND < 40 ppt                    | ND                | 12                            | ND < 90 ppt                    | ND < 30 ppt                     | ND < 20 ppt                 | NT                           | NT                          | NT                            | NT                                  | 12         |                                 |
| 25-Jul-2016     | 6                           | ND < 10 ppt                    | 6                 | 4                             | ND < 10 ppt                    | ND < 10 ppt                     | ND < 2 ppt                  | 10                           | NT                          | NT                            | NT                                  | 20         |                                 |
| 6-Jun-2017      | 20                          | 5                              | 25                | 16                            | 4                              | 4                               | 1                           | 38                           | NT                          | NT                            | NT                                  | 88         |                                 |
| 1-Aug-2017      | 17.9                        | 6.11                           | 24.01             | 8.6                           | 2.65                           | 3.71                            | ND < 4 ppt                  | 25.1                         | NT                          | NT                            | NT                                  | 64.07      |                                 |
| 24-Aug-2017     | 22.3                        | 4.25                           | 26.55             | 12.5                          | 4.24                           | 3.16                            | ND < 4.44                   | 30.2                         | NT                          | NT                            | NT                                  | 76.65      | sample tap; well off-line since |
| 24-Aug-2017     | 19.5                        | 4.98                           | 24.48             | 11.4                          | 3.60                           | 3.87                            | ND < 4.19                   | 28.2                         | NT                          | NT                            | NT                                  | 71.55      | yard hydrant; well off-line     |
| 19-Sep-2017     | 19.5                        | 5.59                           | 25.09             | 11.1                          | 3.22                           | 2.52                            | ND < 4.30                   | 31.1                         | NT                          | NT                            | NT                                  | 73.03      | yard hydrant; well off-line     |
| 17-Oct-2017     | 18.5                        | 4.90                           | 23.40             | 11.1                          | 3.16                           | 2.97                            | 1.29                        | 29.1                         | 8                           | 33.5                          | ND                                  | 112.52     | yard hydrant; well off-line     |
| 15-Nov-2017     | 23.9                        | 3.65                           | 27.55             | 13.5                          | 3.46                           | 2.05                            | ND < 4.76                   | 35.4                         | 9.79                        | 42.1                          | ND < 4.76                           | 133.85     | yard hydrant; well off-line     |

|             |             |             |           |             |             |             |             |            |           |           |           |                      |                                   |
|-------------|-------------|-------------|-----------|-------------|-------------|-------------|-------------|------------|-----------|-----------|-----------|----------------------|-----------------------------------|
| 13-Dec-2017 | 19.9        | 5.20        | 25.10     | 12.3        | 3.49        | 2.43        | 0.986       | 33.00      | 8.69      | 37.6      | ND        | 123.596              | yard hydrant; well off-line       |
| 23-Jan-2018 | 18.5        | 4.31        | 22.81     | 13.9        | 3.09        | 3.92        | 2.03        | 35.20      | 10.1      | 47        | ND        | 138.050              | yard hydrant; well off-line       |
| 13-Feb-2018 | 20.3        | 3.41        | 23.71     | 14.7        | 3.52        | 2.56        | ND < 4.15   | 39.70      | 9.82      | 45.6      | ND < 4.15 | 139.610              | sample tap; well off-line         |
| 13-Feb-2018 | 21.7        | 4.90        | 26.60     | 14.4        | 3.36        | 2.55        | ND < 4.32   | 41.70      | 10.3      | 46        | ND < 4.32 | 144.900              | yard hydrant; well off-line       |
| 9-Aug-2018  | 18.3        | 5.98        | 24.28     | 10.6        | 3.05        | 3.03        | 1.22        | 29.70      | 8.88      | 34.1      | ND < 4.16 | 114.860              | yard hydrant; well off-line       |
| 11-Feb-2019 | 28.1        | 5.92        | 34.02     | 16.5        | 4.05        | 3.90        | 2.13        | 42.9       | 13.0      | 50.3      | 10.2      | 177.0                | yard hydrant; well off-line       |
| Well 8A     |             |             |           |             |             |             |             |            |           |           |           |                      |                                   |
| 16-Sep-2014 | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND                   | Wells 8A and 20 combined effluent |
| 7-Apr-2015  | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND                   | Wells 8A and 20 combined effluent |
| 25-Jul-2016 | 2           | ND < 10 ppt | 2         | 1           | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt  | 1          | NT        | NT        | NT        | 4                    | Well 8A raw alone                 |
| 1-Aug-2017  | 1.35        | 1.96        | 3.31      | ND < 4 ppt  | ND < 4 ppt  | 2.41        | ND < 4 ppt  | ND < 4 ppt | NT        | NT        | NT        | 5.72                 | Well 8A raw alone                 |
| 24-Aug-2017 | 4.46        | 2.00        | 6.46      | ND < 4.24   | ND < 4.24   | 2.11        | ND < 4.24   | ND < 4.24  | NT        | NT        | NT        | 8.57                 | Well 8A raw alone                 |
| 20-Sep-2017 | 2.10        | 1.76        | 3.86      | ND < 4.22   | ND < 4.22   | ND < 4.22   | ND < 4.22   | ND < 4.22  | NT        | NT        | NT        | 3.86                 | Well 8A raw alone                 |
| 18-Oct-2017 | 1.39        | 2.69        | 4.08      | ND < 4.19   | ND < 4.19   | ND < 4.19   | ND < 4.19   | ND < 4.19  | ND < 4.19 | ND < 4.19 | ND        | 4.08                 |                                   |
| 15-Nov-2017 | 1.69        | 2.05        | 3.74      | ND < 4.65   | ND < 4.65   | ND < 4.65   | ND < 4.65   | ND < 4.65  | ND < 4.65 | ND < 4.65 | ND        | 3.74                 |                                   |
| 13-Dec-2017 | 3.16        | ND < 4.27   | 3.16      | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27  | 0.782     | ND < 4.27 | ND        | 3.942                |                                   |
| 23-Jan-2018 | 1.81        | 1.62        | 3.43      | ND < 4.19   | ND < 4.19   | 1.56        | ND < 4.19   | ND < 4.19  | 0.774     | ND < 4.19 | ND        | 5.764                |                                   |
| 13-Feb-2018 | 3.32        | 1.29        | 4.61      | ND < 4.27   | ND < 4.27   | 1.16        | ND < 4.27   | ND < 4.27  | 1.35      | ND < 4.27 | ND        | 7.12                 |                                   |
| 2-May-2018  | 2.49        | ND < 4.22   | 2.49      | ND < 4.22   | ND < 4.22   | ND < 4.22   | ND < 4.22   | ND < 4.22  | 1.02      | ND < 4.22 | ND < 4.22 | 3.51                 |                                   |
| 9-Aug-2018  | 2.89        | 1.79        | 4.68      | 0.701       | ND < 4.20   | 1.19        | ND < 4.20   | ND < 4.20  | 1.77      | 1.43      | ND < 4.20 | 9.771                |                                   |
| 7-Nov-2018  | 2.27        | 1.94        | 4.21      | ND < 4.39   | ND < 4.39   | 1.24        | ND < 4.39   | ND < 4.39  | ND < 4.39 | ND < 4.39 | ND < 4.39 | 5.45                 |                                   |
| 11-Feb-2019 | 2.68        | 2.41        | 5.09      | 0.702       | ND < 4.25   | 1.07        | ND < 4.25   | ND < 4.25  | 1.92      | 1.43      | ND < 4.25 | 10.212               |                                   |
| 7-May-2019  | 2.52        | 1.44        | 3.96      | 1.11        | ND < 4.36   | ND < 4.36   | ND < 4.36   | ND < 4.36  | 1.31      | ND < 4.36 | ND < 4.36 | 6.38                 |                                   |
| Well 20     |             |             |           |             |             |             |             |            |           |           |           |                      |                                   |
| 25-Jul-2016 | 1           | ND < 10 ppt | 1         | ND < 2 ppt  | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt  | ND < 2 ppt | NT        | NT        | NT        | 1                    |                                   |
| 24-Aug-2017 | 1.45        | ND < 4.38   | 1.45      | ND < 4.38   | ND < 4.38   | 1.85        | ND < 4.38   | ND < 4.38  | NT        | NT        | NT        | 3.30                 |                                   |
| 15-Nov-2017 | ND < 4.47   | ND < 4.47   | ND        | ND < 4.47   | ND < 4.47   | ND < 4.47   | ND < 4.47   | ND < 4.47  | ND < 4.47 | ND < 4.47 | ND        | ND                   |                                   |
| 13-Dec-2017 | ND < 4.25   | ND < 4.25   | ND        | ND < 4.25   | ND < 4.25   | 1.2         | ND < 4.25   | ND < 4.25  | ND < 4.25 | ND < 4.25 | ND        | 1.20                 |                                   |
| 15-Feb-2018 | 1.10        | ND < 4.27   | 1.10      | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27  | ND < 4.27 | ND < 4.27 | ND        | 1.10                 |                                   |
| 9-Aug-2018  | 1.30        | ND < 4.21   | 1.30      | ND < 4.21   | ND < 4.21   | 1.08        | ND < 4.21   | ND < 4.21  | 1.42      | ND < 4.21 | ND < 4.21 | 3.80                 |                                   |
| 7-Nov-2018  | ND < 4.60   | ND < 4.60   | ND < 4.60 | ND < 4.60   | ND < 4.60   | ND < 4.60   | ND < 4.60   | ND < 4.60  | ND < 4.60 | ND < 4.60 | ND < 4.60 | ND < 4.60            |                                   |
| 11-Feb-2019 | 0.968       | ND < 4.36   | 0.968     | ND < 4.36   | ND < 4.36   | ND < 4.36   | ND < 4.36   | ND < 4.36  | ND < 4.36 | ND < 4.36 | ND < 4.36 | 0.968                |                                   |
| Well 21     |             |             |           |             |             |             |             |            |           |           |           |                      |                                   |
| 25-Jul-2016 | ND < 2 ppt  | ND < 10 ppt | ND        | ND < 2 ppt  | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt  | ND < 2 ppt | NT        | NT        | NT'       | ND                   |                                   |
| 20-Sep-2017 | ND < 4.40   | ND < 4.40   | ND        | ND < 4.40   | ND < 4.40   | ND < 4.40   | ND < 4.40   | ND < 4.40  | NT        | NT        | NT'       | ND < 4.40            |                                   |
| 15-Aug-2018 | ND < 4.23   | ND < 4.23   | ND        | ND < 4.23   | ND < 4.23   | ND < 4.23   | ND < 4.23   | ND < 4.23  | ND < 4.23 | ND < 4.23 | ND < 4.23 | ND < 4.23 and blanks | trace PFBA and PFHxDA in sample   |
| Well 9      |             |             |           |             |             |             |             |            |           |           |           |                      |                                   |
| 16-Sep-2014 | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND                   |                                   |
| 10-Mar-2015 | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND                   |                                   |
| 25-Jul-2016 | 3           | ND < 10 ppt | 3         | 1           | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt  | 3          | NT        | NT        | NT        | 7                    |                                   |
| 6-Jun-2017  | 5           | 3           | 8         | 2           | 2           | 1           | 0.6         | 3          | NT        | NT        | NT        | 16.6                 |                                   |
| 24-Aug-2017 | 4.46        | 3.18        | 7.64      | ND < 4.32   | ND < 4.32   | 1.51        | ND < 4.32   | ND < 4.32  | NT        | NT        | NT        | 9.15                 |                                   |
| 19-Sep-2017 | 2.74        | 3.23        | 5.97      | ND < 4.10   | ND < 4.10   | 1.32        | ND < 4.10   | ND < 4.10  | NT        | NT        | NT        | 7.29                 |                                   |
| 18-Oct-2017 | 3.78        | 1.29        | 5.07      | ND < 4.19   | ND < 4.19   | 1.21        | ND < 4.19   | ND < 4.19  | ND < 4.19 | 1.73      | ND        | 8.01                 |                                   |
| 2-May-2018  | 5.86        | 1.48        | 7.34      | ND < 4.34   | ND < 4.34   | ND < 4.34   | ND < 4.34   | ND < 4.34  | 1.97      | 3.84      | ND < 4.34 | 13.15                |                                   |
| 9-Aug-2018  | 4.31        | 3.29        | 7.60      | 1.29        | 1.98        | 1.66        | ND < 4.28   | 2.88       | 2.66      | 2.83      | ND < 4.28 | 20.9                 |                                   |
| 7-Nov-2018  | 4.71        | 3.59        | 8.30      | 1.26        | 2.56        | 2.09        | ND < 4.49   | 3.21       | 2.97      | 1.51      | ND < 4.49 | 21.9                 |                                   |
| 11-Feb-2019 | 4.63        | 3.44        | 8.07      | 1.62        | 1.94        | 1.64        | ND < 4.17   | 2.40       | 2.57      | 2.75      | ND < 4.17 | 20.99                |                                   |
| 7-May-2019  | 3.29        | 5.43        | 8.72      | 1.42        | 2.55        | 1.74        | ND < 4.12   | 2.36       | 1.58      | 2.71      | ND < 4.12 | 21.08                |                                   |
| Well 11     |             |             |           |             |             |             |             |            |           |           |           |                      |                                   |
| 16-Sep-2014 | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND                   |                                   |
| 10-Mar-2015 | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND                   |                                   |
| 25-Jul-2016 | 3           | ND < 10 ppt | 3         | 1           | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt  | 4          | NT        | NT        | NT        | 8                    |                                   |
| 6-Jun-2017  | 6           | 2           | 8         | 4           | 2           | 2           | ND < 2 ppt  | 8          | NT        | NT        | NT        | 24                   |                                   |
| 24-Aug-2017 | 3.13        | 2.33        | 5.46      | ND < 4.28   | ND < 4.28   | 1.71        | ND < 4.28   | ND < 4.28  | NT        | NT        | NT        | 7.17                 |                                   |
| 19-Sep-2017 | 2.67        | 0.866       | 3.536     | ND < 4.24   | ND < 4.24   | ND < 4.24   | ND < 4.24   | 4.44       | NT        | NT        | NT        | 7.976                |                                   |
| 17-Oct-2017 | 2.38        | 1.42        | 3.8       | 1.42        | ND < 4.24   | ND < 4.24   | ND < 4.24   | ND < 4.24  | ND < 4.24 | ND < 4.24 | 6.56      | 11.78                |                                   |
| 15-Nov-2017 | 4.28        | 0.929       | 5.209     | 2.78        | ND < 4.41   | ND < 4.41   | ND < 4.41   | 7.09       | 3.06      | 9.15      | ND        | 27.289               |                                   |
| 13-Dec-2017 | 4.35        | 2.68        | 7.03      | 2.66        | ND < 4.36   | 2.54        | ND < 4.36   | 7.42       | 2.62      | 9.03      | ND        | 31.30                |                                   |
| 23-Jan-2018 | 5.21        | 1.15        | 6.36      | 3.04        | 2.31        | 2.62        | ND < 4.20   | ND < 4.20  | 2.94      | 11.3      | ND        | 28.57                |                                   |
| 13-Feb-2018 | 7.44        | 2.29        | 9.73      | 2.88        | 2.83        | 1.32        | ND < 4.21   | 9.05       | 3.25      | 10.8      | ND        | 39.86                |                                   |
| 2-May-2018  | 7.16        | 1.78        | 8.44      | 3.28        | ND < 4.19   | 1.53        | ND < 4.19   | ND < 4.19  | 3.03      | 9.88      | ND < 4.19 | 26.16                |                                   |
| 9-Aug-2018  | 4.97        | 2.71        | 7.68      | 2.00        | ND < 4.21   | 1.60        | ND < 4.21   | 5.53       | 2.68      | 5.68      | ND < 4.21 | 25.17                |                                   |
| 7-Nov-2018  | 6.49        | 2.03        | 8.52      | 3.47        | ND < 4.44   | 1.31        | ND < 4.44   | 10.50      | 3.26      | 12.00     | ND < 4.44 | 39.06                |                                   |
| 11-Feb-2019 | 8.04        | 2.80        | 10.84     | 5.16        | ND < 4.22   | 1.53        | ND < 4.22   | 13.40      | 5.24      | 15.60     | ND < 4.22 | 51.77                |                                   |
| 7-May-2019  | 8.27        | 2.01        | 10.28     | 5.41        | 2.92        | 1.62        | ND < 4.23   | 14.80      | 4.39      | 15.50     | ND < 4.23 | 54.92                |                                   |

|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
|-------------------------------|------------|-------------|-------|------------|-------------|-------------|------------|------------|-----------|-----------|-----------|--------|-----------------------------------|
| Mill Road Wells Treated Blend |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 9-Jul-2018                    | 11.7       | 3.78        | 15.48 | 6.85       | 2.38        | 1.71        | ND < 4.11  | 18         | 6.04      | 20.1      | ND < 4.11 | 70.56  | Well 6 in service<br>Well 6 OFF   |
| 14-Aug-2018                   | 3.96       | 3.66        | 7.62  | 1.47       | 2.45        | 1.17        | ND < 4.38  | 4.18       | 2.24      | 4.95      | ND < 4.38 | 24.08  |                                   |
| 18-Sep-2018                   | 4.05       | 2.86        | 6.91  | 1.69       | ND < 4.21   | 1.04        | ND < 4.21  | 4.17       | 2.26      | 4.65      | ND < 4.21 | 20.72  |                                   |
| 10-Oct-2018                   | 3.61       | 3.02        | 6.63  | 1.05       | ND < 4.38   | 1.83        | ND < 4.38  | 4.45       | 2.54      | 5.23      | ND < 4.38 | 21.73  |                                   |
| 7-Nov-2018                    | 6.03       | 2.20        | 8.23  | 2.27       | 2.19        | 1.68        | ND < 4.34  | 6.91       | 2.91      | 7.83      | ND < 4.34 | 32.02  |                                   |
| 8-Jan-2019                    | 6.64       | ND < 4.31   | 6.64  | ND < 4.31  | ND < 4.31   | ND < 4.31   | ND < 4.31  | 10.6       | ND < 4.31 | 12.0      | 11.6      | 40.84  |                                   |
| 2-Apr-2019                    | 5.53       | 2.47        | 8.00  | 3.21       | ND < 4.26   | ND < 4.26   | ND < 4.26  | 7.52       | 3.12      | 9.3       | ND < 4.26 | 31.10  |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 10                       |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | 1          | ND < 10 ppt | 1     | ND < 2 ppt | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | ND < 2 ppt | NT        | NT        | NT        | 1      |                                   |
| 28-Aug-2017                   | ND < 4.24  | ND < 4.24   | ND    | ND < 4.24  | ND < 4.24   | ND < 4.24   | ND < 4.24  | ND < 4.24  | NT        | NT        | NT        | ND     |                                   |
| 14-Nov-2017                   | 1.33       | ND < 4.34   | 1.33  | ND < 4.34  | ND < 4.34   | ND < 4.34   | ND < 4.34  | ND < 4.34  | ND < 4.34 | ND < 4.34 | ND        | 1.33   |                                   |
| 14-Feb-2018                   | 1.26       | ND < 4.22   | 1.26  | ND < 4.22  | ND < 4.22   | ND < 4.22   | ND < 4.22  | ND < 4.22  | ND < 4.22 | ND < 4.22 | ND        | 1.26   |                                   |
| 2-May-2018                    | 2.18       | ND < 4.13   | 2.18  | ND < 4.13  | ND < 4.13   | ND < 4.13   | ND < 4.13  | ND < 4.13  | 1.64      | ND < 4.13 | ND < 4.13 | 3.82   |                                   |
| 9-Aug-2018                    | 1.45       | ND < 4.23   | 1.45  | ND < 4.23  | ND < 4.23   | 1.11        | ND < 4.23  | ND < 4.23  | 1.81      | ND < 4.23 | ND < 4.23 | 4.37   |                                   |
| 11-Feb-2019                   | ND < 4.14  | 0.988       | 0.988 | ND < 4.14  | ND < 4.14   | 1.49        | ND < 4.14  | ND < 4.14  | 2.34      | ND < 4.14 | ND < 4.14 | 4.818  |                                   |
| 7-May-2019                    | 1.01       | ND < 4.15   | 1.01  | ND < 4.15  | ND < 4.15   | ND < 4.15   | ND < 4.15  | ND < 4.15  | 1.51      | ND < 4.15 | ND < 4.15 | 2.52   |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 12                       |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | 2          | ND < 10 ppt | 2     | ND < 2 ppt | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | 1          | NT        | NT        | NT        | 3      |                                   |
| 28-Aug-2017                   | ND < 4.26  | 1.12        | 1.12  | ND < 4.26  | ND < 4.26   | 1.43        | ND < 4.26  | ND < 4.26  | NT        | NT        | NT        | 2.55   |                                   |
| 14-Nov-2017                   | 1.56       | ND < 4.35   | 1.56  | ND < 4.35  | ND < 4.35   | ND < 4.35   | ND < 4.35  | ND < 4.35  | 1.70      | 1.77      | ND        | 5.03   |                                   |
| 14-Feb-2018                   | 2.73       | ND < 4.26   | 2.73  | ND < 4.26  | ND < 4.26   | ND < 4.26   | ND < 4.26  | ND < 4.26  | 2.41      | ND < 4.26 | 2.20      | 7.34   |                                   |
| 2-May-2018                    | 3.60       | ND < 4.19   | 3.60  | ND < 4.19  | ND < 4.19   | 1.44        | ND < 4.19  | ND < 4.19  | 1.48      | ND < 4.19 | ND < 4.19 | 6.52   |                                   |
| 9-Aug-2018                    | 2.23       | 1.08        | 3.31  | ND < 4.38  | ND < 4.38   | 1.24        | ND < 4.38  | ND < 4.38  | 2.55      | ND < 4.38 | ND < 4.38 | 7.10   |                                   |
| 7-Nov-2018                    | 1.31       | 1.44        | 2.75  | ND < 4.57  | ND < 4.57   | ND < 4.57   | ND < 4.57  | ND < 4.57  | 1.32      | ND < 4.57 | ND < 4.57 | 4.07   |                                   |
| 11-Feb-2019                   | 2.25       | ND < 4.21   | 2.25  | 0.885      | ND < 4.21   | 1.00        | ND < 4.21  | ND < 4.21  | 3.50      | 1.35      | ND < 4.21 | 9.15   |                                   |
| 7-May-2019                    | 3.28       | 1.11        | 4.39  | 1.40       | ND < 4.18   | 1.72        | ND < 4.18  | ND < 4.18  | 3.25      | 1.9       | ND < 4.18 | 12.66  |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 13B                      |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | 1          | ND < 10 ppt | 1     | ND < 2 ppt | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | ND < 2 ppt | NT        | NT        | NT        | 1      |                                   |
| 28-Aug-2017                   | ND < 4.43  | ND < 4.43   | ND    | ND < 4.43  | ND < 4.43   | ND < 4.43   | ND < 4.43  | ND < 4.43  | NT        | NT        | NT        | ND     |                                   |
| 14-Nov-2017                   | ND <4.43   | ND <4.43    | ND    | ND <4.43   | ND <4.43    | ND <4.43    | ND <4.43   | ND <4.43   | ND <4.43  | ND <4.43  | ND        | ND     |                                   |
| 14-Feb-2018                   | 1.05       | ND < 4.15   | 1.05  | ND < 4.15  | ND < 4.15   | ND < 4.15   | ND < 4.15  | ND < 4.15  | ND < 4.15 | ND < 4.15 | ND        | 1.05   |                                   |
| 2-May-2018                    | 1.54       | ND < 4.24   | 1.54  | ND < 4.24  | ND < 4.24   | ND < 4.24   | ND < 4.24  | ND < 4.24  | ND < 4.24 | ND < 4.24 | ND < 4.24 | 1.54   |                                   |
| 9-Aug-2018                    | 1.44       | ND < 4.53   | 1.44  | ND < 4.53  | ND < 4.53   | ND < 4.53   | ND < 4.53  | ND < 4.53  | 1.87      | ND < 4.53 | ND < 4.53 | 3.712  | PFHxDA = 0.402                    |
| 20-May-2019                   | 0.699      | ND < 4.14   | 0.699 | ND < 4.14  | ND < 4.14   | ND < 4.14   | ND < 4.14  | ND < 4.14  | 1.28      | ND < 4.14 | ND < 4.14 | 1.979  |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 16                       |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | 3          | ND < 10 ppt | 3     | 1          | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | 2          | NT        | NT        | NT        | 6      |                                   |
| 28-Aug-2017                   | 2.79       | 0.922       | 3.712 | ND < 4.18  | 3.23        | ND < 4.18   | ND < 4.18  | 4.00       | NT        | NT        | NT        | 10.942 |                                   |
| 14-Nov-2017                   | 2.96       | ND < 4.41   | 2.96  | 1.21       | 2.09        | ND < 4.41   | ND < 4.41  | ND < 4.41  | 2.46      | 2.05      | ND        | 10.77  |                                   |
| 14-Feb-2018                   | 4.09       | 1.20        | 5.29  | 0.975      | 2.98        | ND < 4.15   | ND < 4.15  | ND < 4.15  | 2.42      | 1.59      | ND        | 13.255 |                                   |
| 2-May-2018                    | 3.71       | ND < 4.80   | 3.71  | 1.90       | 3.57        | 1.58        | ND < 4.80  | ND < 4.80  | 2.99      | 2.40      | ND < 4.80 | 16.15  |                                   |
| 9-Aug-2018                    | 6.01       | 2.07        | 8.08  | 2.39       | 2.27        | ND < 4.54   | ND < 4.54  | 3.57       | 4.23      | 2.31      | ND < 4.54 | 22.85  |                                   |
| 7-Nov-2018                    | 3.17       | 1.59        | 4.76  | 0.967      | 2.84        | ND < 4.52   | ND < 4.52  | ND < 4.52  | 2.10      | ND < 4.52 | ND < 4.52 | 10.667 |                                   |
| 11-Feb-2019                   | 4.91       | ND < 4.18   | 4.91  | 2.40       | 2.29        | 1.12        | ND < 4.18  | 3.87       | 3.41      | 2.92      | ND < 4.18 | 20.92  |                                   |
| 7-May-2019                    | 4.75       | ND < 4.21   | 4.75  | 1.95       | 3.27        | 1.10        | ND < 4.21  | 4.11       | 2.65      | 2.31      | ND < 4.21 | 20.14  |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 17                       |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | 2          | ND < 10 ppt | 2     | ND < 2 ppt | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | 1          | NT        | NT        | NT        | 3      |                                   |
| 14-Nov-2017                   | 2.61       | ND < 4.31   | 2.61  | 0.649      | 2.46        | ND < 4.31   | ND < 4.31  | ND < 4.31  | 1.55      | ND < 4.31 | ND        | 7.269  |                                   |
| 15-Feb-2018                   | 5.03       | ND < 4.14   | 5.03  | ND < 4.14  | 3.29        | 1.32        | ND < 4.14  | ND < 4.14  | 2.28      | 1.39      | ND        | 13.31  |                                   |
| 2-May-2018                    | 5.61       | ND < 4.43   | 5.61  | ND < 4.43  | 2.60        | ND < 4.43   | ND < 4.43  | ND < 4.43  | 2.90      | ND < 4.43 | ND < 4.43 | 11.11  |                                   |
| 15-Aug-2018                   | 4.82       | 2.35        | 7.17  | 0.994      | 3.21        | ND < 4.41   | ND < 4.41  | ND < 4.41  | 3.59      | 1.97      | ND < 4.41 | 16.934 | trace PFHxDA in sample and blanks |
| 7-Nov-2018                    | 4.14       | 1.47        | 5.61  | 0.795      | 2.55        | ND < 4.34   | ND < 4.34  | 2.59       | 2.31      | ND < 4.34 | ND < 4.34 | 13.855 |                                   |
| 19-Feb-2019                   | 3.25       | 1.16        | 4.41  | ND < 4.29  | ND < 4.29   | 1.30        | ND < 4.29  | ND < 4.29  | 2.09      | ND < 4.29 | ND < 4.29 | 7.80   |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 18                       |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | 1          | ND < 10 ppt | 1     | ND < 2 ppt | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | ND < 2 ppt | NT        | NT        | NT        | 1      |                                   |
| 16-Oct-2017                   | ND < 4.25  | ND < 4.25   | ND    | ND < 4.25  | ND < 4.25   | ND < 4.25   | ND < 4.25  | ND < 4.25  | ND < 4.25 | ND < 4.25 | ND        | ND     |                                   |
| 14-Nov-2017                   | 1.68       | ND < 4.21   | 1.68  | ND < 4.21  | 1.99        | ND < 4.21   | ND < 4.21  | ND < 4.21  | ND < 4.21 | ND < 4.21 | ND        | 3.67   |                                   |
| 15-Feb-2018                   | 1.66       | ND < 4.24   | 1.66  | ND < 4.24  | 2.44        | ND < 4.24   | ND < 4.24  | ND < 4.24  | 1.04      | ND < 4.24 | ND        | 5.14   |                                   |
| 2-May-2018                    | 3.07       | ND < 4.05   | 3.07  | ND < 4.05  | ND < 4.05   | ND < 4.05   | ND < 4.05  | ND < 4.05  | ND < 4.05 | ND < 4.05 | ND < 4.05 | 3.07   |                                   |
| 9-Aug-2018                    | 2.49       | ND < 4.29   | 2.49  | ND < 4.29  | ND < 4.29   | ND < 4.29   | ND < 4.29  | ND < 4.29  | 1.69      | ND < 4.29 | ND < 4.29 | 4.18   |                                   |
| 19-Feb-2019                   | 1.77       | 0.987       | 2.757 | ND < 4.16  | 1.86        | ND < 4.16   | ND < 4.16  | ND < 4.16  | 1.23      | ND < 4.16 | ND < 4.16 | 5.847  |                                   |
| 7-May-2019                    | 1.81       | 1.17        | 2.98  | ND < 4.32  | 2.07        | ND < 4.32   | ND < 4.32  | ND < 4.32  | ND < 4.32 | ND < 4.32 | ND < 4.32 | 5.05   |                                   |
|                               |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| Well 19                       |            |             |       |            |             |             |            |            |           |           |           |        |                                   |
| 25-Jul-2016                   | ND < 2 ppt | ND < 10 ppt | ND    | ND < 2 ppt | ND < 10 ppt | ND < 10 ppt | ND < 2 ppt | ND < 2 ppt | NT        | NT        | NT        | ND     | these results from second vial    |
| 28-Aug-2017                   | ND < 4.26  | ND < 4.26   | ND    | ND < 4.26  | ND < 4.26   | ND < 4.26   | ND < 4.26  | ND < 4.26  | NT        | NT        | NT        | ND     |                                   |
| 20-Sep-2017                   | 0.782      | 0.955       | 1.737 | ND < 4.24  | ND < 4.24   | ND < 4.24   | ND < 4.24  | ND < 4.24  | NT        | NT        | NT        | 1.737  |                                   |
| 15-Feb-2018                   | 1.67       | ND < 4.32   | 1.67  | ND < 4.32  | ND < 4.32   | ND < 4.32   | ND < 4.32  | ND < 4.32  | ND < 4.32 | ND < 4.32 | ND        | 1.67   |                                   |

|                                                 |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
|-------------------------------------------------|-------------|-------------|-----------|-------------|-------------|-------------|-------------|------------|-----------|-----------|-----------|-----------|------------------------------------|
| 15-Aug-2018                                     | 1.67        | 0.911       | 2.581     | ND < 4.41   | ND < 4.41   | ND < 4.41   | ND < 4.41   | ND < 4.41  | 1.53      | ND < 4.41 | ND < 4.41 | 4.111     | trace PFHxDA in sample and blanks  |
| 11-Feb-2019                                     | 2.52        | ND < 4.21   | 2.52      | 0.739       | ND < 4.21   | 1.39        | ND < 4.21   | ND < 4.21  | 2.16      | ND < 4.21 | ND < 4.21 | 6.809     |                                    |
| 20-May-2019                                     | 1.24        | ND < 4.36   | 1.24      | ND < 4.36   | ND < 4.36   | 1.91        | ND < 4.36   | ND < 4.36  | 0.974     | ND < 4.36 | ND < 4.36 | 4.124     |                                    |
| Winnicut Wells Treated Blend                    |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
| 16-Sep-2014                                     | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND        | Wells 10, 12, 13B, 16, 17, 18 & 19 |
| 10-Mar-2015                                     | ND < 20 ppt | ND < 40 ppt | ND        | ND < 10 ppt | ND < 90 ppt | ND < 30 ppt | ND < 20 ppt | NT         | NT        | NT        | NT        | ND        | Wells 10, 12, 13B, 16, 17, 18 & 19 |
| 7-Jun-2017                                      | 2           | ND < 6 ppt  | 2         | ND < 2 ppt  | 1           | ND < 3 ppt  | ND < 2 ppt  | 0.9        | NT        | NT        | NT        | 3.9       | Wells 10, 12, 13B, 16, 17, 18 & 19 |
| 28-Aug-2017                                     | 1.50        | 0.936       | 2.436     | 0.493       | 1.16        | 0.604       | ND < 2.01   | 1.15       | NT        | NT        | NT        | 5.843     |                                    |
| 14-Nov-2017                                     | 1.01        | ND < 4.32   | 1.01      | ND < 4.32   | ND < 4.32   | ND < 4.32   | ND < 4.32   | ND < 4.32  | 1.87      | ND < 4.32 | ND        | 2.88      |                                    |
| 13-Feb-2018                                     | 2.16        | ND < 4.25   | 2.16      | ND < 4.25   | ND < 4.25   | 1.18        | ND < 4.25   | ND < 4.25  | 1.77      | ND < 4.25 | ND        | 5.11      |                                    |
| 17-Apr-2018                                     | 1.94        | ND < 4.10   | 1.94      | ND < 4.10   | ND < 4.10   | ND < 4.10   | ND < 4.10   | ND < 4.10  | 0.912     | ND < 4.10 | ND < 4.10 | 2.852     |                                    |
| 1-May-2018                                      | 1.82        | ND < 4.04   | 1.82      | ND < 4.04   | ND < 4.04   | ND < 4.04   | ND < 4.04   | ND < 4.04  | 2.26      | ND < 4.04 | ND < 4.04 | 4.08      |                                    |
| 6-Jun-2018                                      | 1.70        | 1.37        | 3.07      | ND < 4.20   | 2.43        | 1.98        | ND < 4.20   | ND < 4.20  | 2.50      | ND < 4.20 | ND < 4.20 | 9.98      |                                    |
| 9-Jul-2018                                      | ND < 4.15   | ND < 4.15   | ND        | 1.16        | ND < 4.15   | ND < 4.15   | ND < 4.15   | ND < 4.15  | 1.69      | ND < 4.15 | ND < 4.15 | 2.85      |                                    |
| 14-Aug-2018                                     | 2.16        | 1.47        | 3.63      | ND < 4.33   | ND < 4.33   | ND < 4.33   | ND < 4.33   | ND < 4.33  | 2.06      | ND < 4.33 | ND < 4.33 | 5.69      |                                    |
| 18-Sep-2018                                     | 0.945       | ND < 4.15   | 0.945     | ND < 4.15   | ND < 4.15   | ND < 4.15   | ND < 4.15   | ND < 4.15  | 1.97      | ND < 4.15 | ND < 4.15 | 2.915     |                                    |
| 10-Oct-2018                                     | ND < 4.34   | ND < 4.34   | ND < 4.34 | ND < 4.34   | ND < 4.34   | 1.11        | ND < 4.34   | ND < 4.34  | 1.150     | ND < 4.34 | ND < 4.34 | 2.260     |                                    |
| 7-Nov-2018                                      | 2.76        | 1.60        | 4.36      | ND < 4.48   | 2.54        | ND < 4.48   | ND < 4.48   | ND < 4.48  | 2.030     | ND < 4.48 | ND < 4.48 | 8.930     |                                    |
| 27-Dec-2018                                     | 0.87        | 1.25        | 2.12      | 0.889       | ND < 4.58   | ND < 4.58   | ND < 4.58   | ND < 4.58  | 2.17      | ND < 4.58 | ND < 4.58 | 5.182     |                                    |
| 8-Jan-2019                                      | ND < 4.28   | ND < 4.28   | ND < 4.28 | ND < 4.28   | ND < 4.28   | ND < 4.28   | ND < 4.28   | ND < 4.28  | ND < 4.28 | ND < 4.28 | ND < 4.28 | ND < 4.28 |                                    |
| 2-Apr-2019                                      | 1.64        | ND < 4.11   | 1.64      | 0.977       | ND < 4.11   | 1.23        | ND < 4.11   | ND < 4.11  | 2.60      | ND < 4.11 | ND < 4.11 | 2.447     |                                    |
| DISTRIBUTION SYSTEM LOCATIONS: (DRINKING WATER) |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
| 20 Birch Road, Hampton                          |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
| 1-Aug-2017                                      | 2.94        | 2.17        | 5.11      | ND < 4 ppt  | ND < 4 ppt  | 1.8         | ND < 4 ppt  | ND < 4 ppt | NT        | NT        | NT        | 6.91      | Near Well 7                        |
| Tide Mill PRV, Hampton, Distribution Point      |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
| 28-Aug-2017                                     | 2.61        | 1.63        | 4.24      | 1.08        | 1.46        | 0.793       | ND < 2.04   | 1.99       | NT        | NT        | NT        | 9.563     |                                    |
| 19-Sep-2017                                     | 0.743       | ND < 4.27   | 0.743     | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27  | NT        | NT        | NT        | 0.743     |                                    |
| 17-Oct-2017                                     | 1.74        | ND < 4.15   | 1.74      | 0.769       | ND < 4.15   | ND < 4.15   | ND < 4.15   | ND < 4.15  | ND < 4.15 | 4.18      | ND        | 6.689     |                                    |
| 16-Nov-2017                                     | 1.77        | 1.81        | 3.58      | 1.31        | ND < 4.25   | ND < 4.25   | ND < 4.25   | ND < 4.25  | 2.43      | 5.6       | ND        | 12.92     |                                    |
| 13-Dec-2017                                     | 4.85        | 1.95        | 6.80      | 1.32        | ND < 4.12   | ND < 4.12   | ND < 4.12   | ND < 4.12  | 1.73      | 4.56      | ND        | 14.41     |                                    |
| 23-Jan-2018                                     | 1.87        | ND < 4.24   | 1.87      | 1.58        | ND < 4.24   | 1.6         | ND < 4.24   | 3.59       | 1.98      | 4.66      | ND        | 15.28     |                                    |
| 14-Feb-2018                                     | 5.53        | ND < 4.25   | 5.53      | 1.37        | 2.06        | 1.10        | ND < 4.25   | 5.19       | 2.28      | 6.17      | ND        | 23.7      |                                    |
| 17-Apr-2018                                     | 5.25        | 2.3         | 7.55      | 2.25        | ND < 4.10   | 1.31        | ND < 4.10   | 4.48       | 1.82      | 5.27      | ND < 4.10 | 22.68     |                                    |
| 1-May-2018                                      | 4.37        | 1.65        | 6.02      | ND < 3.86   | 1.95        | 1.29        | ND < 3.86   | ND < 3.86  | 3.15      | 5.89      | ND < 3.86 | 18.30     |                                    |
| 6-Jun-2018                                      | 5.50        | 1.41        | 6.91      | ND < 4.53   | 2.32        | 1.92        | ND < 4.53   | 6.32       | 3.31      | 6.84      | ND < 4.53 | 27.62     |                                    |
| 9-Jul-2018                                      | 4.83        | ND < 4.03   | 4.83      | ND < 4.03   | ND < 4.03   | ND < 4.03   | ND < 4.03   | 8.99       | 3.13      | 8.97      | ND < 4.03 | 25.92     |                                    |
| 14-Aug-2018                                     | 3.25        | 2.49        | 5.74      | 1.18        | 2.24        | 1.52        | ND < 4.18   | 2.82       | 2.29      | 3.45      | ND < 4.18 | 19.24     | trace PFHxDA sample and blanks     |
| 18-Sep-2018                                     | 2.72        | 1.52        | 4.24      | 1.44        | ND < 4.14   | 1.43        | ND < 4.14   | 3.11       | 2.50      | 3.56      | ND < 4.14 | 16.28     |                                    |
| 10-Oct-2018                                     | 3.97        | 0.872       | 4.84      | 1.66        | ND < 4.18   | 1.21        | ND < 4.18   | 3.83       | 2.07      | 3.64      | ND < 4.18 | 17.252    |                                    |
| 7-Nov-2018                                      | 3.91        | 2.75        | 6.66      | 1.57        | 2.08        | ND < 4.34   | ND < 4.34   | 3.87       | 1.77      | 5.02      | ND < 4.34 | 20.97     |                                    |
| 27-Dec-2018                                     | 4.21        | 2.88        | 7.09      | 2.62        | 2.19        | 1.12        | ND < 4.48   | 5.69       | 2.44      | 6.79      | ND < 4.48 | 27.94     |                                    |
| 8-Jan-2019                                      | 4.61        | ND < 4.24   | 4.61      | ND < 4.24   | ND < 4.24   | ND < 4.24   | ND < 4.24   | 5.71       | ND < 4.24 | 6.20      | ND < 4.24 | 16.52     |                                    |
| Exeter Road Tank, Hampton, Distribution Point   |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
| 28-Aug-2017                                     | 2.38        | 1.88        | 4.26      | 1.09        | 1.43        | 0.806       | ND < 2.07   | 2.65       | NT        | NT        | NT        | 10.236    |                                    |
| 19-Sep-2017                                     | 1.1         | 1.04        | 2.14      | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27   | ND < 4.27  | NT        | NT        | NT        | 2.14      |                                    |
| 17-Oct-2017                                     | 2.58        | ND < 4.17   | 2.58      | ND < 4.17   | ND < 4.17   | 1.61        | ND < 4.17   | ND < 4.17  | 1.19      | 2.68      | ND        | 8.06      |                                    |
| 16-Nov-2017                                     | 5.41        | 1.50        | 6.91      | 1.08        | ND < 4.16   | ND < 4.16   | ND < 4.16   | ND < 4.16  | 2.19      | 3.72      | ND        | 13.9      |                                    |
| 13-Dec-2017                                     | 6.04        | 1.22        | 7.26      | 1.10        | ND < 4.12   | 1.27        | ND < 4.12   | 2.51       | 1.57      | 3.95      | ND        | 17.66     |                                    |
| 23-Jan-2018                                     | ND < 4.20   | 1.90        | 1.9       | 1.52        | ND < 4.20   | 1.17        | ND < 4.20   | ND < 4.20  | 1.71      | 6.36      | ND        | 12.66     |                                    |
| 14-Feb-2018                                     | 3.88        | ND < 4.35   | 3.88      | 1.46        | 2.28        | ND < 4.35   | ND < 4.35   | 4.89       | 2.45      | 6.22      | ND        | 21.18     |                                    |
| 17-Apr-2018                                     | 5.09        | 3.02        | 8.11      | 2.27        | 2.07        | 1.44        | ND < 4.15   | 5.25       | 2.05      | 5.14      | ND < 4.15 | 26.33     |                                    |
| 2-May-2018                                      | 5.63        | 1.91        | 7.54      | ND < 4.16   | ND < 4.16   | ND < 4.16   | ND < 4.16   | ND < 4.16  | 2.64      | 6.50      | ND < 4.16 | 16.68     |                                    |
| 6-Jun-2018                                      | 4.67        | 3.21        | 7.88      | 2.47        | 2.45        | 2.41        | ND < 4.16   | 6.57       | 3.20      | 6.93      | ND < 4.16 | 31.91     |                                    |
| 9-Jul-2018                                      | 7.07        | 4.08        | 11.15     | 4.17        | 2.02        | 2.36        | ND < 4.21   | 10.9       | 3.30      | 9.89      | ND < 4.21 | 43.79     |                                    |
| 14-Aug-2018                                     | 3.58        | 2.13        | 5.71      | 1.62        | 2.14        | 1.52        | ND < 4.37   | 4.42       | 2.79      | 5.01      | ND < 4.37 | 23.21     | trace PFHxDA sample and blanks     |
| 18-Sep-2018                                     | 2.37        | 2.25        | 4.62      | 1.30        | ND < 4.07   | 1.67        | ND < 4.07   | ND < 4.07  | 2.42      | 2.85      | ND < 4.07 | 13.18     | PFHxDA detected at 0.320 ppt       |
| 10-Oct-2018                                     | 2.25        | 1.28        | 3.53      | ND < 3.86   | ND < 3.86   | ND < 3.86   | ND < 3.86   | ND < 3.86  | 1.53      | 1.38      | ND < 3.86 | 6.44      |                                    |
| 7-Nov-2018                                      | 3.62        | 2.40        | 6.02      | 0.993       | ND < 4.82   | ND < 4.82   | ND < 4.82   | 3.39       | 1.45      | 3.43      | ND < 4.82 | 15.283    |                                    |
| 27-Dec-2018                                     | 2.09        | 2.23        | 4.32      | 2.06        | ND < 4.55   | ND < 4.55   | ND < 4.55   | 3.37       | 2.04      | 3.73      | ND < 4.55 | 15.52     |                                    |
| 8-Jan-2019                                      | ND < 4.22   | ND < 4.22   | ND < 4.22 | ND < 4.22   | ND < 4.22   | ND < 4.22   | ND < 4.22   | ND < 4.22  | ND < 4.22 | ND < 4.22 | ND < 4.22 | ND < 4.22 |                                    |
| 2-Apr-2019                                      | 2.81        | 1.89        | 4.70      | 1.27        | ND < 4.49   | ND < 4.49   | ND < 4.49   | 2.63       | 2.15      | 2.84      | ND < 4.49 | 13.59     |                                    |
| Mill Road Tank, Hampton, Distribution Point     |             |             |           |             |             |             |             |            |           |           |           |           |                                    |
| 1-Aug-2017                                      | 4.08        | 3.27        | 7.35      | ND < 4 ppt  | ND < 4 ppt  | 1.9         | ND < 4 ppt  | ND < 4 ppt | NT        | NT        | NT        | 9.25      | Blend of Mill Road Wells           |
| 28-Aug-2017                                     | 3.72        | 1.36        | 5.08      | 2.39        | 1.71        | 1.12        | ND < 2.05   | 5.05       | NT        | NT        | NT        | 15.35     | Well 6 off-line since 8/14/17      |
| 19-Sep-2017                                     | 2.46        | 1.74        | 4.20      | 0.777       | ND < 4.14   | 1.19        | ND < 4.14   | ND < 4.14  | NT        | NT        | NT        | 6.167     |                                    |
| 17-Oct-2017                                     | 3.27        | 1.34        | 4.61      | ND < 4.23   | ND < 4.23   | 1.82        | ND < 4.23   | ND < 4.23  | 1.3       | 3.24      | ND        | 10.97     |                                    |
| 16-Nov-2017                                     | 2.53        | ND < 4.29   | 2.53      | 1.31        | ND < 4.29   | 1.11        | ND < 4.29   | ND < 4.29  | 1.87      | 3.60      | ND        | 10.42     |                                    |
| 13-Dec-2017                                     | 5.13        | ND < 4.20   | 5.13      | 1.15        | ND < 4.20   | 1.50        | ND < 4.20   | 2.51       | 1.56      | 4.10      | ND        | 15.95     |                                    |

|                                                   |           |           |           |           |           |           |           |           |           |           |           |           |                                |
|---------------------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|--------------------------------|
| 23-Jan-2018                                       | 2.95      | ND < 4.16 | 2.95      | 1.93      | ND < 4.16 | 3.04      | ND < 4.16 | 5.72      | 1.91      | 6.07      | ND        | 21.62     |                                |
| 14-Feb-2018                                       | 3.94      | 1.22      | 5.16      | ND < 4.14 | 2.56      | ND < 4.14 | ND < 4.14 | ND < 4.14 | 2.06      | 4.92      | ND        | 14.70     |                                |
| 17-Apr-2018                                       | 5.20      | 2.27      | 7.47      | 2.44      | 2.05      | 1.45      | ND < 4.14 | 5.59      | 2.16      | 5.85      | ND < 4.14 | 27.01     |                                |
| 1-May-2018                                        | 4.60      | ND < 4.21 | 4.60      | 2.36      | ND < 3.99 | ND < 3.99 | ND < 3.99 | ND < 3.99 | 2.40      | 5.75      | ND < 3.99 | 15.11     |                                |
| 6-Jun-2018                                        | 4.23      | 1.67      | 5.90      | 2.46      | 2.18      | 2.15      | ND < 4.16 | 6.62      | 3.25      | 6.49      | ND < 4.16 | 29.05     |                                |
| 9-Jul-2018                                        | 5.81      | 1.11      | 6.92      | ND < 4.21 | 2.43      | 2.87      | ND < 4.21 | 10.6      | 3.37      | 10.50     | ND < 4.21 | 36.69     |                                |
| 14-Aug-2018                                       | 5.40      | 3.07      | 8.47      | 2.57      | 2.24      | 1.76      | ND < 4.33 | 6.91      | 3.31      | 8.31      | ND < 4.33 | 33.57     | trace PFHxDA sample and blanks |
| 18-Sep-2018                                       | 2.81      | 2.56      | 5.37      | 1.39      | ND < 4.22 | 1.12      | ND < 4.22 | 3.67      | 2.04      | 4.10      | ND < 4.22 | 17.70     |                                |
| 10-Oct-2018                                       | 3.52      | 2.39      | 5.91      | 1.49      | ND < 4.20 | 1.48      | ND < 4.20 | 4.04      | 1.91      | 4.16      | ND < 4.20 | 18.99     |                                |
| 7-Nov-2018                                        | 4.19      | 2.81      | 7.00      | 1.23      | ND < 4.37 | ND < 4.37 | ND < 4.37 | 4.87      | 1.79      | 5.11      | ND < 4.37 | 20.00     |                                |
| 27-Dec-2018                                       | 3.87      | 2.13      | 6.00      | 2.93      | ND < 4.50 | 1.40      | ND < 4.50 | 4.95      | 2.53      | 6.11      | ND < 4.50 | 23.92     |                                |
| 8-Jan-2019                                        | ND < 4.31 | ND < 4.31 | ND < 4.31 | ND < 4.31 | ND < 4.31 | ND < 4.31 | ND < 4.31 | 5.00      | ND < 4.31 | 5.28      | ND < 4.31 | 10.28     |                                |
| 2-Apr-2019                                        | 2.28      | ND < 4.21 | 2.28      | 0.690     | ND < 4.21 | ND < 4.21 | ND < 4.21 | ND < 4.21 | 2.40      | ND < 4.21 | ND < 4.21 | 5.37      |                                |
| Maple Road PRV, North Hampton, Distribution Point |           |           |           |           |           |           |           |           |           |           |           |           |                                |
| 19-Sep-2017                                       | ND < 4.19 | 1.25      | 1.25      | ND < 4.19 | ND < 4.19 | ND < 4.19 | ND < 4.19 | ND < 4.19 | NT        | NT        | NT        | 1.25      |                                |
| 17-Oct-2017                                       | ND < 4.18 | 0.852     | 0.852     | ND < 4.18 | ND < 4.18 | ND < 4.18 | ND < 4.18 | ND < 4.18 | ND < 4.18 | ND < 4.18 | ND        | 0.852     |                                |
| 14-Nov-2017                                       | 1.64      | ND < 4.30 | 1.64      | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | 1.47      | ND < 4.30 | ND        | 3.11      |                                |
| 13-Dec-2017                                       | 3.08      | ND < 4.13 | 3.08      | ND < 4.13 | ND < 4.13 | 1.20      | ND < 4.13 | ND < 4.13 | 1.14      | ND < 4.13 | ND        | 5.42      |                                |
| 23-Jan-2018                                       | 1.01      | ND < 4.23 | 1.01      | ND < 4.23 | ND < 4.23 | 2.57      | ND < 4.23 | ND < 4.23 | 1.25      | ND < 4.23 | ND        | 4.83      |                                |
| 14-Feb-2018                                       | 2.71      | ND > 4.25 | 2.71      | ND > 4.25 | ND > 4.25 | 1.14      | ND > 4.25 | ND > 4.25 | 1.19      | ND < 4.25 | ND        | 5.04      |                                |
| 17-Apr-2018                                       | 2.53      | 1.71      | 4.24      | ND < 4.10 | ND < 4.10 | ND < 4.10 | ND < 4.10 | ND < 4.10 | 0.772     | ND < 4.10 | ND < 4.10 | 5.012     |                                |
| 2-May-2018                                        | 3.75      | ND < 4.16 | 3.75      | ND < 4.16 | ND < 4.16 | ND < 4.16 | ND < 4.16 | ND < 4.16 | 1.68      | ND < 4.16 | ND < 4.16 | 5.43      |                                |
| 6-Jun-2018                                        | ND < 4.19 | 1.30      | 1.30      | ND < 4.16 | 2.28      | 1.65      | ND < 4.16 | ND < 4.16 | 2.03      | ND < 4.16 | ND < 4.16 | 7.26      |                                |
| 9-Jul-2018                                        | 6.30      | 1.63      | 7.93      | ND < 4.11 | ND < 4.11 | 2.51      | ND < 4.11 | 8.15      | 3.12      | 9.52      | ND < 4.11 | 31.23     |                                |
| 14-Aug-2018                                       | 2.50      | 1.72      | 4.22      | 0.688     | 2         | 1.42      | ND < 4.34 | ND < 4.34 | 1.99      | 1.84      | ND < 4.34 | 12.158    | trace PFHxDA sample and blanks |
| 18-Sep-2018                                       | 2.13      | 1.35      | 3.48      | ND < 4.16 | ND < 4.16 | ND < 4.16 | ND < 4.16 | 3.14      | 2.13      | 3.68      | ND < 4.16 | 12.43     |                                |
| 12-Oct-2018                                       | 2.81      | 1.36      | 4.17      | 0.959     | ND < 4.18 | ND < 4.18 | ND < 4.18 | 3.05      | 1.92      | 3.42      | ND < 4.18 | 13.519    |                                |
| 7-Nov-2018                                        | 3.84      | 2.05      | 5.89      | 1.48      | ND < 4.48 | ND < 4.48 | ND < 4.48 | 5.30      | 1.96      | 5.44      | ND < 4.48 | 20.07     |                                |
| 27-Dec-2018                                       | 3.34      | 1.89      | 5.23      | 2.24      | ND > 4.95 | ND > 4.95 | ND > 4.95 | 4.76      | 2.37      | 5.71      | ND > 4.95 | 20.31     |                                |
| 8-Jan-2019                                        | 4.48      | ND < 4.25 | 4.48      | ND < 4.25 | ND < 4.25 | ND < 4.25 | ND < 4.25 | 5.69      | ND < 4.25 | 6.64      | ND < 4.25 | 16.81     |                                |
| Fire Station, North Hampton, Distribution Point   |           |           |           |           |           |           |           |           |           |           |           |           |                                |
| 19-Sep-2017                                       | ND < 4.15 | 0.984     | 0.984     | ND < 4.15 | ND < 4.15 | ND < 4.15 | ND < 4.15 | ND < 4.15 | NT        | NT        | NT        | 0.984     |                                |
| 18-Oct-2017                                       | ND < 4.14 | ND < 4.14 | ND        | ND < 4.14 | ND < 4.14 | ND < 4.14 | ND < 4.14 | ND < 4.14 | ND < 4.14 | ND < 4.14 | ND        | ND < 4.14 |                                |
| 16-Nov-2017                                       | 3.87      | ND < 4.22 | 3.87      | ND < 4.22 | ND < 4.22 | ND < 4.22 | ND < 4.22 | ND < 4.22 | 1.68      | ND < 4.22 | ND        | 5.55      |                                |
| 13-Dec-2017                                       | ND < 4.30 | ND < 4.30 | ND        | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | 1.28      | ND < 4.30 | ND        | 1.28      |                                |
| 23-Jan-2018                                       | ND < 4.20 | ND < 4.20 | ND        | ND < 4.20 | ND < 4.20 | 1.70      | ND < 4.20 | ND < 4.20 | 1.30      | ND < 4.20 | ND        | 3         |                                |
| 15-Feb-2018                                       | 1.90      | ND < 4.34 | 1.90      | ND < 4.34 | ND < 4.34 | ND < 4.34 | ND < 4.34 | ND < 4.34 | 1.13      | ND < 4.34 | 2.19      | 5.22      |                                |
| 17-Apr-2018                                       | 1.69      | ND < 4.11 | 1.69      | ND < 4.11 | ND < 4.11 | ND < 4.11 | ND < 4.11 | ND < 4.11 | 0.834     | ND < 4.11 | ND < 4.11 | 2.524     |                                |
| 1-May-2018                                        | 1.79      | ND < 4.17 | 1.79      | ND < 3.95 | ND < 3.95 | ND < 3.95 | ND < 3.95 | ND < 3.95 | 1.76      | ND < 3.95 | ND < 3.95 | 3.55      |                                |
| 6-Jun-2018                                        | 1.36      | 1.30      | 2.66      | ND < 4.38 | 2.24      | 1.37      | ND < 4.38 | ND < 4.38 | 1.98      | ND < 4.38 | ND < 4.38 | 8.25      |                                |
| 9-Jul-2018                                        | 2.22      | ND < 4.19 | 2.22      | ND < 4.19 | ND < 4.19 | ND < 4.19 | ND < 4.19 | ND < 4.19 | 1.72      | ND < 4.19 | 2.73      | 6.67      |                                |
| 14-Aug-2018                                       | 2.08      | 1.11      | 3.19      | ND < 4.40 | ND < 4.40 | ND < 4.40 | ND < 4.40 | ND < 4.40 | 2.54      | ND < 4.40 | ND < 4.40 | 5.73      | trace PFHxDA sample and blanks |
| 18-Sep-2018                                       | 1.44      | 1.36      | 2.80      | ND < 4.10 | ND < 4.10 | 1.15      | ND < 4.10 | ND < 4.10 | 1.76      | ND < 4.10 | ND < 4.10 | 5.71      |                                |
| 12-Oct-2018                                       | 0.935     | ND < 4.26 | 0.935     | ND < 4.26 | ND < 4.26 | ND < 4.26 | ND < 4.26 | ND < 4.26 | 1.33      | ND < 4.26 | ND < 4.26 | ND < 4.26 |                                |
| 7-Nov-2018                                        | 1.96      | ND < 4.49 | 1.96      | ND < 4.49 | ND < 4.49 | ND < 4.49 | ND < 4.49 | ND < 4.49 | 1.30      | ND < 4.49 | ND < 4.49 | 3.26      |                                |
| 27-Dec-2018                                       | 1.58      | 1.03      | 2.61      | ND < 4.44 | ND < 4.44 | 1.23      | ND < 4.44 | ND < 4.44 | 1.97      | ND < 4.44 | ND < 4.44 | 5.81      |                                |
| 8-Jan-2019                                        | 5.00      | ND < 4.22 | 5.00      | ND < 4.22 | ND < 4.22 | ND < 4.22 | ND < 4.22 | 6.30      | ND < 4.22 | 6.35      | ND < 4.22 | 17.65     |                                |
| 2-Apr-2019                                        | 1.94      | ND < 4.26 | 1.94      | ND < 4.26 | ND < 4.26 | ND < 4.26 | ND < 4.26 | ND < 4.26 | 2.44      | ND < 4.26 | ND < 4.26 | 4.38      |                                |
| Rye Store, Rye, Distribution Point                |           |           |           |           |           |           |           |           |           |           |           |           |                                |
| 19-Sep-2017                                       | 0.943     | 1.41      | 2.353     | ND < 4.19 | ND < 4.19 | ND < 4.19 | ND < 4.19 | ND < 4.19 | NT        | NT        | NT        | 2.353     |                                |
| 17-Oct-2017                                       | 1.08      | 1.40      | 2.48      | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND < 4.30 | ND        | 2.48      |                                |
| 16-Nov-2017                                       | 1.42      | 1.69      | 3.11      | ND < 4.04 | ND < 4.04 | 1.25      | ND < 4.04 | ND < 4.04 | 1.42      | ND < 4.04 | ND        | 5.78      |                                |
| 13-Dec-2017                                       | 5.99      | 1.28      | 7.27      | ND < 4.29 | ND < 4.29 | 1.44      | ND < 4.29 | ND < 4.29 | 1.25      | ND < 4.29 | ND        | 5.99      |                                |
| 23-Jan-2018                                       | ND < 4.18 | 0.884     | 0.884     | ND < 4.18 | ND < 4.18 | 1.22      | ND < 4.18 | ND < 4.18 | 0.933     | ND < 4.18 | ND        | 3.037     |                                |
| 14-Feb-2018                                       | 2.31      | ND < 4.18 | 2.31      | ND < 4.18 | ND < 4.18 | 1.49      | ND < 4.18 | ND < 4.18 | 0.978     | ND < 4.18 | ND        | 4.778     |                                |
| 17-Apr-2018                                       | 2.49      | ND < 4.13 | 2.49      | 0.635     | ND < 4.13 | 1.01      | ND < 4.13 | ND < 4.13 | 1.02      | ND < 4.13 | ND < 4.13 | 5.155     |                                |
| 2-May-2018                                        | 3.29      | ND < 4.05 | 3.29      | ND < 4.05 | ND < 4.05 | ND < 4.05 | ND < 4.05 | ND < 4.05 | 1.8       | 1.36      | ND < 4.05 | 6.45      |                                |
| 6-Jun-2018                                        | 2.89      | 1.48      | 4.37      | ND < 4.26 | ND < 4.26 | ND < 4.26 | ND < 4.26 | ND < 4.26 | 1.97      | 1.74      | ND < 4.26 | 8.08      |                                |
| 9-Jul-2018                                        | 3.27      | ND < 4.15 | 3.27      | ND < 4.15 | ND < 4.15 | ND < 4.15 | ND < 4.15 | 4.37      | 2.64      | 5.93      | ND < 4.15 | 16.21     |                                |
| 14-Aug-2018                                       | 3.17      | 2.80      | 5.97      | 1.11      | ND < 4.36 | 1.21      | ND < 4.36 | 3.12      | 2.46      | 3.66      | ND < 4.36 | 17.53     | trace PFHxDA sample and blanks |
| 18-Sep-2018                                       | 3.20      | 2.26      | 5.46      | 1.09      | ND < 4.08 | 1.82      | ND < 4.08 | 2.88      | 2.27      | 3.39      | ND < 4.08 | 16.91     |                                |
| 12-Oct-2018                                       | 3.21      | 1.24      | 4.45      | 1.33      | ND < 4.28 | 1.13      | ND < 4.28 | 3.69      | 1.93      | 3.83      | ND < 4.28 | 16.36     |                                |
| 7-Nov-2018                                        | 4.46      | 1.92      | 6.38      | 1.63      | ND < 4.50 | 1.07      | ND < 4.50 | 5.26      | 1.97      | 5.89      | ND < 4.50 | 22.20     |                                |
| 27-Dec-2018                                       | 4.57      | 0.978     | 5.548     | 2.69      | 2.07      | ND < 4.50 | ND < 4.50 | 4.73      | 2.58      | 5.65      | ND < 4.50 | 23.28     |                                |
| 8-Jan-2019                                        | ND < 4.33 | ND < 4.33 | ND < 4.33 | ND < 4.33 | ND < 4.33 | ND < 4.33 | ND < 4.33 | 5.75      | ND < 4.33 | 6.77      | ND < 4.33 | 12.52     |                                |
| 2-Apr-2019                                        | 3.25      | 1.70      | 4.95      | 1.41      | ND < 4.24 | ND < 4.24 | ND < 4.24 | 2.94      | 2.06      | 3.18      | ND < 4.24 | 14.54     |                                |

PFCs Not Detected In Any Sample:

Perfluorodecanoic acid (PFDA)  
Perfluoroundecanoic acid (PFUnA)  
Perfluorododecanoic acid (PFDoA)  
Perfluorotridecanoic acid (PFTrDA)  
Perfluorotetradecanoic acid (PFTeDA)

Perfluoroheptane sulfonate (PFHpS)  
Perfluorodecane sulfonate (PFDS)  
Perfluorooctanesulfonamide (PFOSA)  
8:2 Perfluorotelomer sulfonate (8:2 FTS)

N-methyl-perfluorooctanesulfonamide (MeFOSA)  
N-methyl-perfluorooctane sulfonamidoethanol (MeFOSE)  
N-methyl-perfluorooctanesulfonamidoacetic acid (MeFOSAA)  
N-ethyl-perfluorooctane sulfonamidoethanol (EtFOSE)  
N-ethyl-perfluorooctane sulfonamide (EtFOSA)  
N-ethyl-perfluorooctanesulfonamidoacetic acid (EtFOSAA)