

**Aquarion Water Company of Massachusetts
PFAS Sampling Results**

Town/City: Oxford

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL	MASSDEP	Other PFAS Tested		
									PFAS (6)	MCL	PFBS	PFHxA	PFTA
Oxford	No. Main St Well #1, POE	2019 Q4 (October)	1	1	ND	ND	ND	ND	2	20	1	ND	ND
	No. Main St Well #2, POE	2019 Q4 (October)	1	1	ND	1	ND	ND	3	20	1	ND	ND
	Nelson St Wells #3, POE	2019 Q4 (October)	2	1	1	1	ND	ND	5	20	1	ND	ND
	Nelson St Wells #3, Raw	2020 Q2 (April)	2	ND	ND	ND	ND	ND	2	20	1	ND	ND

Definitions:

MCL - Maximum Contaminant Level

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.

Raw - Sample collected before treatment.