

**Aquarion Water Company of New Hampshire
PFAS Sampling Results**

All Results Reported as parts per trillion (ppt)

Sample Location	Sample Date	PFOA	PFOA	PFOS	PFOA	PFHxS	PFOA	PFNA	PFNA	Other PFAS Tested				
			Running Annual Average		Running Annual Average		Running Annual Average			Running Annual Average	PFPeA	PFHxA	PFBA	PFBS
	NH DES MCL		12		15		18		11	none	none	none	none	none
Mill Rd WTP	Jan. 2020	14		5		2		ND		23	18	6	2	7
	May 2020	11		4		ND		ND		20	18	5	3	7
	July 2020	9		4		ND		ND		ND	13	ND	2	6
	Dec 2020	7	10	4	4	2	1	ND	0	12	11	4	2	4
Well 5A	Feb. 2020	5		3		ND		ND		3	2	2	2	ND
	April 2020	4		4		ND		ND		ND	ND	ND	ND	ND
	July 2020	5		4		ND		ND		ND	3	ND	ND	ND
	Oct. 2020	4		6		ND		ND		ND	ND	ND	2	ND
	Jan. 2021	3	4	3	4	ND	0	ND	0	ND	ND	ND	ND	ND
Little River WTP	Jan. 2020	5		3		ND		ND		3	2	2	3	ND
	April 2020	5		3		ND		ND		2	ND	ND	3	ND
	July 2020	3		ND		ND		ND		ND	ND	ND	ND	ND
	Oct 2020	3	4	ND	2	ND	0	ND	0	ND	ND	ND	2	ND
Well 14	March 2020	6		4		ND		ND		5	5	ND	3	ND
	April 2020	6		6		ND		ND		6	5	2	3	2
	July 2020	3	5	ND	4	ND	0	ND	0	ND	ND	ND	ND	ND
	Q4 2020	NT		NT		NT		NT		NT	NT	NT	NT	NT
Winnicut Rd WTP A (Wells 10,12,16,17)	Feb. 2020	3		ND		ND		ND		ND	2	2	ND	ND
	April 2020	3		ND		ND		ND		ND	2	2	ND	ND
	July 2020	3		ND		ND		ND		ND	ND	ND	ND	ND
	Nov 2020	ND		ND		ND		ND		ND	ND	ND	ND	ND
	Jan. 2021	ND	2	ND	0	ND	0	ND	0	ND	ND	2	ND	ND
Winnicut Rd WTP B (Wells 10,12,16,18)	Jan. 2020	3		ND		ND		ND		2	2	2	ND	ND
	April 2020	3		ND		ND		ND		ND	2	ND	ND	ND
	July 2020	2		ND		ND		ND		ND	ND	ND	ND	ND
	Nov 2020	ND		ND		ND		ND		ND	ND	ND	ND	ND
	Jan. 2021	ND	1	ND	0	ND	0	ND	0	ND	ND	ND	ND	ND
Winnicut Rd WTP C (Wells 10,12,13B,16, 19)	March 2020	2		ND		ND		ND		ND	ND	ND	ND	ND
	April 2020	3		ND		ND		ND		ND	ND	ND	ND	ND
	July 2020	2		ND		ND		ND		ND	ND	ND	ND	ND
	Nov 2020	ND	2	ND	0	ND	0	ND	0	ND	ND	ND	ND	ND

Footnote:

Compliance based on running annual average of previous four quarters.

Definitions:

MCL - Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

ND - Not Detected

NT - Not Tested

WTP - Water Treatment Plant