



Compliance Lead Testing Aquarion Water Company of Connecticut

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps, and testing the lead concentration in these samples. A water system is considered to be in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

	Town(s) Served	System Name	Most Recent Testing			Previous Testing		
			Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
1	BETHEL	CHIMNEY HEIGHTS	2019	2	Yes	2016	None Detected	Yes
2	BETHEL	BERKSHIRE CORP	2020	None Detected	Yes	2017	None Detected	Yes
3	BRIDGEPORT, EASTON, FAIRFIELD, MONROE, NEWTOWN, NORWALK, REDDING, SHELTON, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON	MAIN SYSTEM	2020b	2	Yes	2020a	2	Yes
4	BROOKFIELD	BROOKWOOD	2020	1	Yes	2017	2	Yes
5	BROOKFIELD	BUTTERNUT	2018	4	Yes	2018	9	Yes
6	BROOKFIELD	BROOKFIELD MAIN	2019	1	Yes	2016	3	Yes
7	BROOKFIELD	HICKORY HILLS	2020b	None Detected	Yes	2020a	2	Yes
8	BROOKFIELD	INDIAN FIELDS	2018	4	Yes	2015	11	Yes
9	BROOKFIELD	WESTERN BROOKFIELD	2020	5	Yes	2019	5	Yes
11	CORNWALL	CORNWALL	2020	3	Yes	2017	1	Yes

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps, and testing the lead concentration in these samples. A water system is considered to be in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

	Town(s) Served	System Name	Most Recent Testing			Previous Testing		
			Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
12	DANBURY	INDIAN SPRING	2020	3	Yes	2017	3	Yes
13	DANBURY	CEDAR HEIGHTS	2018	2	Yes	2015	3	Yes
14	DANBURY	KEN OAKS	2018	5	Yes	2015	3	Yes
15	DANBURY	PEARCE MANOR	2020b	2	Yes	2020a	4	Yes
16	DANBURY	HOLLANDALE ESTATES	2020	None Detected	Yes	2017	1	Yes
17	DANBURY	ROLLING RIDGE	2020	None Detected	Yes	2017	None Detected	Yes
18	DARIEN	NOROTON (DARIEN)	2020	2	Yes	2017	2	Yes
19	DERBY	EAST DERBY	2020	1	Yes	2017	1	Yes
20	EAST HAMPTON	EAST HAMPTON	2018	None Detected	Yes	2015	None Detected	Yes
21	GOSHEN	TYLER LAKE HEIGHTS	2018	1	Yes	2015	1	Yes
22	GREENWICH	GREENWICH	2019	2	Yes	2016	2	Yes
23	KENT	KENT	2018	3	Yes	2015	3	Yes
24	LEBANON	LEBANON	2018	None Detected	Yes	2015	None Detected	Yes

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps, and testing the lead concentration in these samples. A water system is considered to be in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

	Town(s) Served	System Name	Most Recent Testing			Previous Testing		
			Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
25	LITCHFIELD	LITCHFIELD	2019	2	Yes	2016	None Detected	Yes
26	MANSFIELD	VALLEY VIEW	2018	2	Yes	2015	7	Yes
27	MARLBOROUGH	BIRCHWOOD ESTATES	2019	None Detected	Yes	2016	2	Yes
28	MARLBOROUGH	MARLBOROUGH	2020b	3	Yes	2020a	3	Yes
29	MIDDLEBURY	WEST SHORE	2020b	None Detected	Yes	2020a	None Detected	Yes
30	NEW CANAAN	NEW CANAAN	2020	7	Yes	2017	2	Yes
31	NEW FAIRFIELD	BALL POND	2019	4	Yes	2016	4	Yes
31	NEW FAIRFIELD	BIRCHES	2018	None Detected	Yes	2015	2	Yes
32	NEW FAIRFIELD	DUNHAM POND	2018	4	Yes	2015	4	Yes
33	NEW FAIRFIELD	FIELDSTONE RIDGE	2020	2	Yes	2017	None Detected	Yes
34	NEW FAIRFIELD	INTERLAKEN WC	2020	1	Yes	2017	1	Yes
35	NEW FAIRFIELD	OAKWOOD ACRES	2018	6	Yes	2015	9	Yes
32	NEW FAIRFIELD	POSSUM RIDGE	2020b	3	Yes	2020a	2	Yes

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps, and testing the lead concentration in these samples. A water system is considered to be in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

	Town(s) Served	System Name	Most Recent Testing			Previous Testing		
			Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
33	NEW MILFORD	CARMEN HILL	2020	6	Yes	2017	3	Yes
34	NEW MILFORD	DEAN HEIGHTS	2019	None Detected	Yes	2016	3	Yes
35	NEW MILFORD	FOREST HILLS	2018	2	Yes	2015	1	Yes
36	NEW MILFORD	LAUREL RIDGE/LAUREL VIEW	2020b	None Detected	Yes	2020a	None Detected	Yes
37	NEW MILFORD	MEADOWBROOK	2019	3	Yes	2016	4	Yes
38	NEW MILFORD	NEW MILFORD REGIONAL	2020b	2	Yes	2020a	1	Yes
39	NEW MILFORD	PARK GLEN	2019	None Detected	Yes	2016	None Detected	Yes
40	NEW MILFORD	PLEASANT VIEW	2019	None Detected	Yes	2016	None Detected	Yes
41	NEW MILFORD	TWIN OAKS	2018	None Detected	Yes	2015	1	Yes
42	NEWTOWN	CHESTNUT TREE HILL	2019	2	Yes	2017	4	Yes
43	NEWTOWN	SANDY HOOK	2019	4	Yes	2016	5	Yes
44	NEWTOWN	NEWTOWN MAIN	2018	2	Yes	2015	None Detected	Yes
45	NORFOLK	NORFOLK	2018	None Detected	Yes	2015	None Detected	Yes

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps, and testing the lead concentration in these samples. A water system is considered to be in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

Town(s) Served	System Name	Most Recent Testing			Previous Testing		
		Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
46 NORTH CANAAN	NORTH CANAAN	2018	2	Yes	2015	1	Yes
47 NORWICH	PLEASURE VALLEY MHP	2020b	None Detected	Yes	2020a	None Detected	Yes
48 OXFORD	HAWKSTONE	2018	None Detected	Yes	2015	None Detected	Yes
49 OXFORD	OXFORD TOWN CENTER	2020	None Detected	Yes	2019	None Detected	Yes
50 RIDGEFIELD	TURNER HILL BARNUM	2018	None Detected	Yes	2015	None Detected	Yes
51 RIDGEFIELD	TURNER HILL MCKEON	2018	3	Yes	2015	None Detected	Yes
52 RIDGEFIELD	RIDGEFIELD MAIN	2020b	None Detected	Yes	2020a	None Detected	Yes
53 RIDGEFIELD	CRAIGMOOR	2020b	4	Yes	2020a	12	Yes
54 RIDGEFIELD	SCODON	2020b	2	Yes	2020a	2	Yes
55 RIDGEFIELD	RIDGEFIELD KNOLLS	2018	None Detected	Yes	2015	2	Yes
56 SALISBURY	SALISBURY	2018	1	Yes	2015	None Detected	Yes
57 SEYMOUR, OXFORD, BEACON FALLS	VALLEY	2020	2	Yes	2017	4	Yes
58 SHERMAN	TIMBER TRAILS	2020b	None Detected	Yes	2020a	None Detected	Yes

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps, and testing the lead concentration in these samples. A water system is considered to be in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

	Town(s) Served	System Name	Most Recent Testing			Previous Testing		
			Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
59	SIMSBURY	SIMSBURY	2019	4	Yes	2016	4	Yes
60	SOUTHBURY	LAKESIDE	2018	5	Yes	2015	None Detected	Yes
61	STAMFORD	STAMFORD	2020b	2	Yes	2020a	None Detected	Yes
62	STONINGTON	ARLINGTON ACRES	2020	2	Yes	2017	6	Yes
63	STONINGTON	MYSTIC	2020b	None Detected	Yes	2020a	1	Yes
64	SUFFIELD	SUFFIELD	2018	6	Yes	2015	2	Yes
65	WASHINGTON	JUDEA DEPOT	2018	1	Yes	2015	3	Yes
66	WASHINGTON	JUDEA MAIN	2020b	None Detected	Yes	2020a	1	Yes
67	WASHINGTON	QUARRY RIDGE	2020	None Detected	Yes	2017	None Detected	Yes
68	WOLCOTT	CLEARVIEW	2020	1	Yes	2019	2	Yes
69	WOLCOTT	WOODRICH VILLAGE	2018	3	Yes	2015	3	Yes
70	WOODBURY	WOODBURY	2020b	None Detected	Yes	2020a	1	Yes