



Greater Bridgeport System
2018 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	07/12/18	None Detected
2	07/12/18	None Detected
3	07/12/18	None Detected
4	07/12/18	None Detected
5	07/12/18	None Detected
6	07/12/18	None Detected
7	07/12/18	None Detected
8	07/12/18	None Detected
9	07/12/18	None Detected
10	07/12/18	None Detected
11	07/12/18	None Detected
12	07/13/18	None Detected
13	07/13/18	None Detected
14	07/13/18	None Detected
15	07/13/18	None Detected
16	07/13/18	None Detected
17	07/13/18	None Detected
18	07/13/18	None Detected
19	07/13/18	None Detected
20	07/13/18	None Detected
21	07/13/18	None Detected
22	07/13/18	None Detected
23	07/13/18	None Detected
24	07/13/18	None Detected
25	07/13/18	None Detected
26	07/16/18	None Detected
27	07/19/18	None Detected
28	07/19/18	None Detected
29	07/19/18	None Detected
30	07/19/18	None Detected



Rank	Collection Date	Lead Results (ppb)
31	07/19/18	None Detected
32	07/19/18	None Detected
33	07/19/18	None Detected
34	07/19/18	None Detected
35	07/19/18	None Detected
36	07/19/18	None Detected
37	07/13/18	1
38	07/13/18	1
39	07/19/18	1
40	07/12/18	2
41	07/12/18	2
42	07/13/18	2
43	07/13/18	2
44	07/19/18	2
45	08/03/18	2
46	07/23/18	3
47	07/13/18	4
48	07/13/18	4
49	07/19/18	4
50	07/19/18	4
51	07/12/18	5
52	07/19/18	35

PWS ID#: CT0150011

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**