



AQUARION
Water Company

Stewards of the Environment™

Brookfield - Butternut System
2018 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 9

Rank	Collection Date	Lead Results (ppb)
1	06/14/18	None Detected
2	06/14/18	3
3	06/14/18	4
4	06/21/18	5
5	06/14/18	2

PWS ID#: CT0180021

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**