



Brookfield - Hickory Hills System
2020 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	10/08/20	None Detected
2	10/08/20	None Detected
3	10/08/20	None Detected
4	10/08/20	None Detected
5	10/08/20	None Detected
6	10/08/20	None Detected
7	10/08/20	None Detected
8	10/08/20	None Detected
9	10/08/20	None Detected
10	10/08/20	None Detected
11	10/08/20	2

PWS ID#: CT0180101

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**