



Danbury - Cedar Heights System 2018 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	06/14/18	None Detected
2	06/14/18	1
3	06/14/18	1
4	07/08/18	1
5	06/14/18	2
6	06/14/18	2
7	06/14/18	2
8	06/14/18	3
9	06/14/18	3
10	06/14/18	5

PWS ID#: CT0340131

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**