



Danbury - Indian Spring System
2020 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	10/22/20	None Detected
2	10/22/20	None Detected
3	10/22/20	None Detected
4	10/22/20	None Detected
5	10/22/20	None Detected
6	10/22/20	None Detected
7	10/22/20	None Detected
8	10/22/20	1
9	10/22/20	1
10	10/22/20	2
11	10/22/20	2
12	10/30/20	4
13	10/22/20	8

PWS ID#: CT0340191

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**