



Danbury – Indian Springs System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	06/16/2023	None Detected
2	06/16/2023	None Detected
3	06/16/2023	None Detected
4	06/16/2023	None Detected
5	08/11/2023	None Detected
6	06/16/2023	1
7	06/16/2023	1
8	06/16/2023	1
9	08/11/2023	1
10	06/16/2023	2
11	06/16/2023	25

PWS ID#: CT0340191

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.