



AQUARION
Water Company

Stewards of the Environment™

Danbury - Ken Oaks System
2015 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	06/17/2015	None Detected
2	06/17/2015	None Detected
3	06/17/2015	None Detected
4	06/17/2015	None Detected
5	06/17/2015	None Detected
6	06/17/2015	7

PWS ID#: CT0340211

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**