



## **Danbury - Pearce Manor System 2020 Lead Compliance Testing Results**

**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 4**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	05/28/20	None Detected
2	05/28/20	None Detected
3	05/28/20	None Detected
4	05/28/20	None Detected
5	05/28/20	None Detected
6	05/28/20	None Detected
7	05/28/20	1
8	05/28/20	1
9	05/28/20	1
10	05/28/20	2
11	05/28/20	4
12	05/28/20	7

**PWS ID#: CT0340081**

**\*For additional information, please refer to the \*.pdf entitled: "CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration."**