



***Danbury - Pearce Manor System***  
***2020 Lead Compliance Testing Results***  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 2**

| <b>Rank</b> | <b>Collection Date</b> | <b>Lead Results (ppb)</b> |
|-------------|------------------------|---------------------------|
| 1           | 10/22/20               | None Detected             |
| 2           | 10/22/20               | None Detected             |
| 3           | 10/22/20               | None Detected             |
| 4           | 10/22/20               | None Detected             |
| 5           | 10/22/20               | None Detected             |
| 6           | 10/22/20               | None Detected             |
| 7           | 10/22/20               | None Detected             |
| 8           | 10/22/20               | None Detected             |
| 9           | 10/22/20               | None Detected             |
| 10          | 10/22/20               | None Detected             |
| 11          | 10/22/20               | 1                         |
| 12          | 10/22/20               | 3                         |
| 13          | 10/22/20               | 4                         |

**PWS ID#: CT0340081**

**\*For additional information, please refer to the \*.pdf entitled: "CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration."**