



Darien - Noroton System 2017 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	06/30/17	None Detected
2	06/30/17	None Detected
3	06/30/17	None Detected
4	06/30/17	None Detected
5	06/30/17	None Detected
6	06/30/17	None Detected
7	06/30/17	None Detected
8	06/30/17	None Detected
9	06/30/17	None Detected
10	06/30/17	None Detected
11	06/30/17	None Detected
12	06/30/17	None Detected
13	06/30/17	None Detected
14	06/30/17	None Detected
15	06/30/17	None Detected
16	06/30/17	None Detected
17	06/30/17	None Detected
18	06/30/17	None Detected
19	06/30/17	None Detected
20	06/30/17	None Detected
21	06/30/17	None Detected
22	06/30/17	None Detected
23	06/30/17	None Detected
24	06/30/17	1
25	06/30/17	1
26	06/30/17	1
27	06/30/17	2
28	06/30/17	3



AQUARION
Water Company

Stewards of the Environment™

29	06/30/17	4
30	06/30/17	1

PWS ID#: CT0350011

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**