



Kent System
2018 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	06/08/18	None Detected
2	06/08/18	None Detected
3	06/08/18	None Detected
4	06/08/18	1
5	06/08/18	1
6	06/08/18	2
7	06/08/18	2
8	06/08/18	3
9	06/08/18	3
10	06/08/18	5

PWS ID#: CT0680011

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**