



Mansfield – Valley View System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	07/14/2023	None Detected
2	07/14/2023	None Detected
3	07/14/2023	None Detected
4	07/14/2023	None Detected
5	07/14/2023	None Detected
6	07/14/2023	1
7	07/14/2023	2
8	07/14/2023	3
9	07/14/2023	3

PWS ID#: CT0780211

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.