



## Middlebury – West Shore System 2022 Lead Compliance Testing Results

System is in Compliance

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 3**

Rank	Collection Date	Lead Results (ppb)
1	07-15-2022	None Detected
2	07-15-2022	None Detected
3	07-15-2022	None Detected
4	07-15-2022	None Detected
5	07-15-2022	2
6	07-15-2022	2
7	07-15-2022	6

**PWS ID#: CT0819061**

**\*ppb = parts per billion**

**For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.**