



**New Canaan System**  
**2020 Lead Compliance Testing Results**  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 7**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	06/26/20	None Detected
2	06/26/20	None Detected
3	06/26/20	None Detected
4	06/26/20	None Detected
5	06/26/20	None Detected
6	06/26/20	None Detected
7	06/26/20	None Detected
8	06/26/20	None Detected
9	06/26/20	None Detected
10	06/26/20	None Detected
11	06/26/20	None Detected
12	06/26/20	None Detected
13	06/26/20	None Detected
14	06/26/20	None Detected
15	06/26/20	None Detected
16	06/26/20	None Detected
17	06/26/20	None Detected
18	06/26/20	None Detected
19	06/26/20	None Detected
20	06/26/20	None Detected
21	06/26/20	None Detected
22	06/26/20	None Detected
23	06/26/20	None Detected
24	07/15/20	None Detected
25	06/26/20	3
26	06/26/20	4
27	06/26/20	7
28	06/26/20	7



**AQUARION**  
Water Company

*Stewards of the Environment™*

29	06/26/20	10
30	07/03/20	26

**PWS ID#: CT0900011**

**\*For additional information, please refer to the \*.pdf entitled: “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration.”**