



***New Fairfield - Birches System***  
***2018 Lead Compliance Testing Results***  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = None Detected**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	07/18/18	None Detected
2	07/18/18	None Detected
3	07/18/18	None Detected
4	07/18/18	None Detected
5	07/18/18	None Detected
6	07/18/18	2

**PWS ID#: CT0911091**

**\*For additional information, please refer to the \*.pdf entitled: "CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration."**