



New Fairfield - Fieldstone Ridge
2020 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	06/19/20	None Detected
2	06/19/20	None Detected
3	06/19/20	None Detected
4	06/19/20	None Detected
5	06/19/20	None Detected
6	06/19/20	None Detected
7	06/19/20	None Detected
8	06/19/20	2
9	06/19/20	2
10	06/19/20	2

PWS ID#: CT0910021

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**