



## **New Fairfield – Fieldstone Ridge System 2023 Lead Compliance Testing Results**

**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = None Detected**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	03-16-2023	None Detected
2	03-16-2023	None Detected
3	03-16-2023	None Detected
4	03-16-2023	None Detected
5	03-16-2023	None Detected
6	03-16-2023	1

**PWS ID#: CT0910021**

**\*ppb = parts per billion**

**For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.**