



New Fairfield – Interlaken System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	06/09/2023	None Detected
2	06/09/2023	None Detected
3	06/09/2023	1
4	06/09/2023	2
5	06/09/2023	3
6	06/09/2023	3

PWS ID#: CT0911061

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.