



***New Fairfield - Oakwood Acres System  
2015 Lead Compliance Testing Results***  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 9**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	06/16/15	1
2	06/16/15	2
3	06/16/15	3
4	06/16/15	5
5	06/16/15	8
6	06/16/15	10

**PWS ID#: CT0910031**

**\*For additional information, please refer to the \*.pdf entitled: “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration.”**