



**New Fairfield - Oakwood Acres System**  
**2018 Lead Compliance Testing Results**  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 6**

Rank	Collection Date	Lead Results (ppb)
1	06/13/18	None Detected
2	06/13/18	2
3	06/13/18	3
4	06/13/18	3
5	06/13/18	3
6	06/14/18	6

**PWS ID#: CT0910031**

**\*For additional information, please refer to the \*.pdf entitled: "CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration."**