



***New Fairfield - Possum Ridge System
2019 Lead Compliance Testing Results***
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

| Rank | Collection Date | Lead Results (ppb) |
|------|-----------------|--------------------|
| 1 | 05/10/19 | None Detected |
| 2 | 05/10/19 | None Detected |
| 3 | 05/10/19 | None Detected |
| 4 | 05/10/19 | None Detected |
| 5 | 05/10/19 | None Detected |
| 6 | 05/10/19 | None Detected |
| 7 | 05/10/19 | None Detected |
| 8 | 05/10/19 | 2 |
| 9 | 05/10/19 | 2 |
| 10 | 05/10/19 | 2 |

PWS ID#: CT0910041

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**