



New Fairfield - Possum Ridge System 2019 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	09/30/19	None Detected
2	09/30/19	None Detected
3	09/30/19	None Detected
4	09/30/19	None Detected
5	09/30/19	1
6	09/30/19	1
7	09/30/19	1
8	09/30/19	9

PWS ID#: CT0910041

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**