



***New Fairfield - Possum Ridge System
2020 Lead Compliance Testing Results***
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	10/09/20	None Detected
2	10/09/20	None Detected
3	10/09/20	None Detected
4	10/09/20	None Detected
5	10/09/20	None Detected
6	10/09/20	None Detected
7	10/09/20	2
8	10/09/20	8

PWS ID#: CT0910041

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**