



New Fairfield – Possum Ridge System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	09-23-2022	None Detected
2	09-23-2022	None Detected
3	09-23-2022	None Detected
4	09-23-2022	None Detected
5	09-23-2022	None Detected
6	09-23-2022	None Detected
7	09-23-2022	1
8	09-23-2022	2
9	09-23-2022	2
10	09-23-2022	2

PWS ID#: CT0910041

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.