



New Fairfield – Possum Ridge System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	03-16-2023	None Detected
2	03-16-2023	None Detected
3	03-16-2023	None Detected
4	03-16-2023	None Detected
5	03-16-2023	None Detected
6	03-16-2023	None Detected
7	04-20-2023	None Detected
8	03-16-2023	1
9	03-16-2023	1
10	04-20-2023	1
11	03-16-2023	2

PWS ID#: CT0910041

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.