



***New Milford - Carmen Hill System  
2017 Lead Compliance Testing Results***  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 3**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	09/20/17	None Detected
2	09/20/17	None Detected
3	10/06/17	2
4	09/20/17	3
5	10/06/17	3
6	10/06/17	4

**PWS ID#: CT0960101**

**\*For additional information, please refer to the \*.pdf entitled: “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration.”**