



***New Milford - Carmen Hill System
2020 Lead Compliance Testing Results
System is in Compliance***

90th Percentile Lead Concentration (ppb)* = 6

Rank	Collection Date	Lead Results (ppb)
1	07/16/20	None Detected
2	07/16/20	None Detected
3	07/16/20	None Detected
4	07/16/20	1
5	07/16/20	6
6	07/16/20	6

PWS ID#: CT0960101

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**