



## ***New Milford - Dean Heights System 2016 Lead Compliance Testing Results***

**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 3**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	07/29/16	None Detected
2	07/29/16	None Detected
3	07/29/16	None Detected
4	07/29/16	None Detected
5	09/01/16	None Detected
6	07/29/16	1
7	07/29/16	2
8	07/27/16	5

**PWS ID#: CT0960161**

**\*For additional information, please refer to the \*.pdf entitled: “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration.”**