



New Milford - Meadowbrook System 2016 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	08/02/16	None Detected
2	08/03/16	None Detected
3	08/03/16	None Detected
4	08/03/16	None Detected
5	08/04/16	None Detected
6	08/04/16	None Detected
7	08/04/16	None Detected
8	08/02/16	1
9	08/03/16	1
10	08/04/16	1
11	08/05/16	3
12	08/10/16	4
13	08/04/16	7

PWS ID#: CT0960201

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**