



## New Milford – Meadowbrook System 2022 Lead Compliance Testing Results

System is in Compliance

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 6**

Rank	Collection Date	Lead Results (ppb)
1	07-08-2022	None Detected
2	07-08-2022	None Detected
3	07-08-2022	None Detected
4	07-08-2022	None Detected
5	07-08-2022	None Detected
6	07-08-2022	1
7	07-08-2022	2
8	07-08-2022	22

**PWS ID#: CT0960201**

**\*ppb = parts per billion**

**For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.**