



***New Milford - Park Glen System
2016 Lead Compliance Testing Results
System is in Compliance***

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	07/23/16	None Detected
2	07/23/16	None Detected
3	07/23/16	None Detected
4	07/23/16	None Detected
5	07/23/16	None Detected
6	07/23/16	None Detected
7	07/23/16	None Detected
8	07/23/16	2

PWS ID#: CT0969361

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**