



Norwich – Pleasure Valley System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	10-21-2022	None Detected
2	10-21-2022	None Detected
3	10-21-2022	None Detected
4	10-21-2022	None Detected
5	10-21-2022	None Detected
6	10-21-2022	None Detected
7	10-21-2022	None Detected
8	10-21-2022	None Detected
9	10-21-2022	1
10	10-21-2022	2

PWS ID#: CT1041001

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.