



Ridgefield - Craigmoor System
2020 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 12

Rank	Collection Date	Lead Results (ppb)
1	05/28/20	None Detected
2	05/28/20	None Detected
3	05/28/20	2
4	05/28/20	2
5	05/28/20	2
6	05/28/20	3
7	05/28/20	4
8	05/28/20	4
9	05/28/20	4
10	05/28/20	5
11	05/28/20	5
12	05/28/20	7
13	05/28/20	9
14	05/28/20	14
15	05/28/20	14

PWS ID#: CT1180071

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**