



Ridgefield – Craigmoor System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	06/22/2023	None Detected
2	06/22/2023	None Detected
3	06/22/2023	None Detected
4	06/22/2023	None Detected
5	06/22/2023	None Detected
6	06/22/2023	2
7	06/22/2023	2
8	06/22/2023	2
9	06/22/2023	2
10	06/28/2023	2
11	06/22/2023	3
12	06/22/2023	5
13	06/22/2023	13

PWS ID#: CT1180071

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.