



Ridgefield Main System 2020 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	04/16/20	None Detected
2	04/16/20	None Detected
3	04/16/20	None Detected
4	04/16/20	None Detected
5	04/16/20	None Detected
6	04/16/20	None Detected
7	04/16/20	None Detected
8	04/16/20	None Detected
9	04/16/20	None Detected
10	04/16/20	None Detected
11	04/16/20	None Detected
12	04/16/20	None Detected
13	04/16/20	None Detected
14	04/16/20	None Detected
15	04/16/20	None Detected
16	04/16/20	None Detected
17	04/16/20	None Detected
18	04/16/20	None Detected
19	04/16/20	None Detected
20	04/16/20	None Detected
22	04/16/20	None Detected
23	04/17/20	None Detected
24	04/17/20	None Detected
25	04/17/20	None Detected
26	04/17/20	None Detected
27	04/17/20	None Detected
28	04/17/20	None Detected
29	04/17/20	None Detected
30	04/17/20	None Detected
31	04/17/20	None Detected



32	04/17/20	None Detected
33	04/17/20	None Detected
34	04/17/20	None Detected
35	04/17/20	None Detected
36	04/17/20	None Detected
37	04/17/20	None Detected
38	04/17/20	None Detected
39	04/17/20	1
40	04/17/20	3
41	04/16/20	11

PWS ID#: CT1180011

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**