



Ridgefield Main System 2020 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	11/12/20	None Detected
2	11/12/20	None Detected
3	11/12/20	None Detected
4	11/12/20	None Detected
5	11/12/20	None Detected
6	11/12/20	None Detected
7	11/12/20	None Detected
8	11/12/20	None Detected
9	11/12/20	None Detected
10	11/12/20	None Detected
11	11/12/20	None Detected
12	11/12/20	None Detected
13	11/12/20	None Detected
14	11/12/20	None Detected
15	11/13/20	None Detected
16	11/13/20	None Detected
17	11/13/20	None Detected
18	11/13/20	None Detected
19	11/13/20	None Detected
20	11/13/20	None Detected
22	11/13/20	None Detected
23	11/13/20	None Detected
24	11/13/20	None Detected
25	11/13/20	None Detected
26	11/13/20	None Detected
27	11/13/20	None Detected
28	11/13/20	None Detected
29	11/13/20	None Detected
30	11/12/20	None Detected
31	12/02/20	None Detected



32	12/03/20	None Detected
33	12/03/20	None Detected
34	11/12/20	1
35	11/12/20	2
36	11/13/20	4
37	11/12/20	9
38	11/13/20	9
39	12/03/20	10
40	11/13/20	13

PWS ID#: CT1180011

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**