

## Ridgefield – Scodon Main System 2021 Lead Compliance Testing Results

System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 2

Rank	Collection Date	Lead Results (ppb)
1	07-14-2021	None Detected
2	07-14-2021	None Detected
3	07-14-2021	None Detected
4	07-14-2021	1
5	07-14-2021	2
6	07-14-2021	2
7	07-14-2021	2
8	07-14-2021	2
9	07-14-2021	2
10	07-19-2021	2

PWS ID#: CT1180041

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled "CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile" on the CT Lead Compliance Reports webpage.