



Salisbury System
2015 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	07/17/2015	None Detected
2	07/17/2015	None Detected
3	07/17/2015	None Detected
4	07/17/2015	None Detected
5	07/17/2015	None Detected
6	07/17/2015	None Detected
7	07/17/2015	None Detected
8	07/17/2015	None Detected
9	07/17/2015	None Detected
10	07/17/2015	3

PWS ID#: CT1220011

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**