

Seymour, Oxford and Becan Falls - Valley System

2020 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	07/02/20	None Detected
2	07/02/20	None Detected
3	07/02/20	None Detected
4	07/02/20	None Detected
5	07/02/20	None Detected
6	07/02/20	None Detected
7	07/02/20	None Detected
8	07/02/20	None Detected
9	07/02/20	None Detected
10	07/02/20	None Detected
11	07/02/20	None Detected
12	07/02/20	None Detected
13	07/02/20	None Detected
14	07/02/20	None Detected
15	07/02/20	None Detected
16	07/02/20	None Detected
17	07/02/20	None Detected
18	07/02/20	None Detected
19	07/02/20	None Detected
20	07/02/20	None Detected
21	07/02/20	None Detected
22	07/02/20	1
23	07/02/20	1
24	07/02/20	1
25	07/02/20	1
26	07/06/20	1
27	07/08/20	1
28	07/02/20	2
29	07/02/20	2
30	07/02/20	2



31	07/02/20	3
32	07/02/20	6
33	07/02/20	7

PWS ID#: CT1240011

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**