



Sherman – Timber Trails System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	07/13/2023	None Detected
2	07/13/2023	None Detected
3	07/13/2023	None Detected
4	07/13/2023	None Detected
5	07/13/2023	None Detected
6	07/13/2023	None Detected
7	07/13/2023	None Detected
8	07/13/2023	None Detected
9	07/13/2023	None Detected
10	07/13/2023	None Detected
11	07/13/2023	None Detected
12	07/13/2023	None Detected
13	07/13/2023	None Detected
14	07/13/2023	None Detected
15	07/13/2023	None Detected
16	07/13/2023	1
17	07/13/2023	3

PWS ID#: CT1270021

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.