

Simsbury System

2016 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	08/16/16	None Detected
2	08/17/16	None Detected
3	08/18/16	None Detected
4	08/18/16	None Detected
5	08/18/16	None Detected
6	08/18/16	None Detected
7	08/18/16	None Detected
8	08/18/16	None Detected
9	08/19/16	None Detected
10	08/19/16	None Detected
11	08/19/16	None Detected
12	08/19/16	None Detected
13	08/19/16	None Detected
14	08/19/16	None Detected
15	08/19/16	None Detected
16	08/19/16	None Detected
17	08/19/16	None Detected
18	08/19/16	None Detected
19	08/19/16	None Detected
20	08/19/16	None Detected
21	08/24/16	None Detected
22	08/18/16	1
23	08/19/16	1
24	08/16/16	2
25	08/19/16	2
26	08/19/16	2
27	08/19/16	4
28	08/18/16	5



AQUARION
Water Company

Stewards of the Environment™

29	08/17/16	8
30	08/18/16	32

PWS ID#: CT1280021

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**