



Southbury - Lakeside System
2018 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 5

Rank	Collection Date	Lead Results (ppb)
1	06/22/2018	None Detected
2	06/22/2018	1
3	06/22/2018	1
4	06/22/2018	2
5	06/22/2018	7

PWS ID#: CT1300031

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**