



Stamford System
2019 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	10/29/20	None Detected
2	10/29/20	None Detected
3	10/29/20	None Detected
4	10/29/20	None Detected
5	10/29/20	None Detected
6	10/29/20	None Detected
7	10/29/20	None Detected
8	10/29/20	None Detected
9	10/29/20	None Detected
10	10/29/20	None Detected
11	10/29/20	None Detected
12	10/29/20	None Detected
13	10/29/20	None Detected
14	10/29/20	None Detected
15	10/29/20	None Detected
16	10/29/20	None Detected
17	10/29/20	None Detected
18	10/29/20	None Detected
19	10/29/20	None Detected
20	10/29/20	None Detected
21	10/29/20	None Detected
22	10/29/20	None Detected
23	10/29/20	None Detected
24	10/29/20	None Detected
25	10/29/20	None Detected
26	10/29/20	None Detected
27	10/29/20	None Detected
28	10/29/20	None Detected
29	10/29/20	None Detected
30	10/29/20	None Detected
31	10/29/20	None Detected
32	10/29/20	None Detected



33	10/29/20	None Detected
34	10/29/20	None Detected
35	10/29/20	None Detected
36	10/29/20	None Detected
37	10/29/20	None Detected
38	10/29/20	None Detected
39	10/29/20	None Detected
40	10/29/20	None Detected
41	10/29/20	None Detected
42	10/29/20	None Detected
43	10/29/20	None Detected
44	10/29/20	None Detected
45	10/29/20	None Detected
46	10/29/20	None Detected
47	10/29/20	None Detected
48	10/29/20	None Detected
49	10/29/20	None Detected
50	10/29/20	None Detected
51	10/29/20	None Detected
52	10/29/20	None Detected
53	10/29/20	None Detected
54	10/29/20	None Detected
54	10/29/20	None Detected
55	10/29/20	None Detected
56	10/29/20	None Detected
57	10/29/20	None Detected
58	10/29/20	None Detected
59	10/29/20	None Detected
60	10/29/20	None Detected
61	10/29/20	None Detected
62	10/29/20	None Detected
63	10/29/20	None Detected
64	10/29/20	None Detected
65	10/29/20	None Detected
66	10/29/20	None Detected
67	10/29/20	None Detected
68	10/29/20	None Detected
69	10/29/20	None Detected
70	10/29/20	None Detected
71	10/29/20	None Detected
72	10/29/20	None Detected



73	10/29/20	None Detected
74	10/29/20	None Detected
75	10/29/20	None Detected
76	10/29/20	None Detected
77	10/29/20	None Detected
78	10/29/20	None Detected
79	10/29/20	None Detected
80	10/29/20	None Detected
81	10/29/20	None Detected
82	11/02/20	None Detected
83	11/03/20	None Detected
84	12/04/20	None Detected
85	12/08/20	None Detected
86	12/08/20	None Detected
87	10/29/20	1
88	10/29/20	1
89	10/29/20	1
90	10/29/20	2
91	10/29/20	2
92	10/29/20	3
93	10/29/20	3
94	10/29/20	4
95	10/29/20	4
96	10/29/20	5
97	10/29/20	6
98	10/29/20	6
99	10/29/20	7
100	10/29/20	7
101	10/29/20	9

PWS ID#: CT135001

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**