



## Stonington – Arlington Acres System 2022 Lead Compliance Testing Results

System is in Compliance

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 1**

Rank	Collection Date	Lead Results (ppb)
1	11-04-2022	None Detected
2	11-04-2022	None Detected
3	11-04-2022	None Detected
4	11-04-2022	None Detected
5	11-04-2022	None Detected
6	11-04-2022	None Detected
7	11-04-2022	None Detected
8	11-04-2022	1
9	11-04-2022	1
10	11-04-2022	1
11	11-04-2022	1
12	11-04-2022	1

**PWS ID#: CT1370071**

**\*ppb = parts per billion**

**For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.**