



Stonington – Arlington Acres System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	04-14-2023	None Detected
2	04-14-2023	None Detected
3	04-14-2023	None Detected
4	04-14-2023	None Detected
5	04-14-2023	None Detected
6	04-19-2023	None Detected
7	04-21-2023	None Detected
8	04-21-2023	None Detected
9	04-14-2023	1
10	04-14-2023	2
11	04-14-2023	2
12	04-21-2023	2
13	04-21-2023	3
14	04-14-2023	6

PWS ID#: CT1370071

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.