



Stonington – Mystic System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	07-29-2022	None Detected
2	07-29-2022	None Detected
3	07-29-2022	None Detected
4	07-29-2022	None Detected
5	07-29-2022	None Detected
6	07-29-2022	None Detected
7	07-29-2022	None Detected
8	07-29-2022	None Detected
9	07-29-2022	None Detected
10	07-29-2022	None Detected
11	07-29-2022	None Detected
12	07-29-2022	None Detected
13	07-29-2022	None Detected
14	07-29-2022	None Detected
15	07-29-2022	None Detected
16	07-29-2022	None Detected
17	07-29-2022	None Detected
18	07-29-2022	None Detected
19	07-29-2022	None Detected
20	07-29-2022	None Detected
21	07-29-2022	None Detected
22	07-29-2022	None Detected
23	07-29-2022	None Detected
24	07-29-2022	None Detected
25	07-29-2022	None Detected
26	07-29-2022	None Detected



27	07-29-2022	None Detected
28	07-29-2022	None Detected
29	07-29-2022	None Detected
30	07-29-2022	None Detected
31	07-29-2022	None Detected
32	07-29-2022	None Detected
33	07-29-2022	None Detected
34	07-29-2022	None Detected
35	07-29-2022	None Detected
36	07-29-2022	None Detected
37	07-29-2022	None Detected
38	07-29-2022	2
39	07-29-2022	4
40	07-29-2022	9

PWS ID#: CT1370011

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.